

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
07/12/2011	ADP003	7.37	3.5	2.6	1.5	4.2	0.29	5.26	0.215	10
14/12/2011	ADP003	7.5	2.5	2.3	1.1	1	0.279	4.71	0.574	10
21/12/2011	ADP003	7.37	2	1.2	1.2	2.1	0.34	5.22	0.645	10
28/12/2011	ADP003	7.21	5	3.6	2	0.7	0.31	6.2	0.488	10
04/01/2012	ADP003	7.2	4.5	3.2	1.3	0.5	0.42	5.97	0.579	10
11/01/2012	ADP003	7.1	3.5	2.1	1.6	5.1	0.5	3.89	0.533	10
18/01/2012	ADP003	6.95	0.5	<0.5	0.7	1.8	0.15	2.93	0.063	16000
25/01/2012	ADP003	7.15	5.5	4.2	1.2	3.9	0.28	2.06	0.067	70
01/02/2012	ADP003	6.93	2.5	2.3	5.4	0.6	0.18	4.22	0.013	22000
08/02/2012	ADP003	7.28	0.5	0.5	1	3.3	0.13	5.03	0.439	10
15/02/2012	ADP003	6.78	0.5	<0.5	1	0.6	0.19	5.36	0.205	40
22/02/2012	ADP003	7.11	0.5	<0.5	0.5	2.1	0.17	2.92	0.14	10
29/02/2012	ADP003	7.39	0.5	<0.5	1.1	0.5	0.27	5.42	0.248	1400
07/03/2012	ADP003	6.99	2.5	<0.5	1	0.8	0.23	3.76	0.313	10
14/03/2012	ADP003	7.35	1.5	1.2	0.8	0.5	0.23	6.32	0.206	10
21/03/2012	ADP003	7.77	0.5	<0.5	1.2	2.9	0.41	3.15	0.477	10
28/03/2012	ADP003	7.23	3.5	2.9	1.1	1.1	0.33	4.12	0.597	10
04/04/2012	ADP003	7.2	1.5	0.5	1	5.5	0.21	5.03	0.291	<10
11/04/2012	ADP003	7.08	3	2.8	1	0.5	0.19	4.84	0.297	<10
18/04/2012	ADP003	7.1	3	2.2	1.6	0.9	0.2	2.88	0.284	80
25/04/2012	ADP003	7.26	4	3.9	1	0.5	0.14	5.52	0.663	20
02/05/2012	ADP003	7.31	5.5	5	1.2	3.7	0.3	3.59	0.337	10
09/05/2012	ADP003	7.69	2.5	1.9	1.1	2.8	0.18	5.97	0.732	20
16/05/2012	ADP003	7.56	1	0.8	1.3	3.4	0.11	5.71	0.591	10
23/05/2012	ADP003	7.28	2.5	2.3	5	4	0.075	7.12	0.013	80000
30/05/2012	ADP003	7.21	3	2.8	4.2	<0.5	0.1	2.75	0.539	21000
06/06/2012	ADP003	7.41	5.5	5.3	1.6	1.9	0.22	4.24	0.303	<10
13/06/2012	ADP003	7.87	18	17.2	3.6	2	0.45	2.77	0.213	390
20/06/2012	ADP003	7.83	3.5	3.3	1.4	2.3	0.15	6.63	0.376	<10
27/06/2012	ADP003	7.47	3.5	3.1	1.4	7.4	0.165	7.06	0.291	<10
04/07/2012	ADP003	7.05	7	6.8	1.6	2	0.27	7.05	0.302	<10
11/07/2012	ADP003	7.08	0.5	0.1	1.1	3.5	0.09	5.93	0.627	10
18/07/2012	ADP003	7.3	1	0.3	0.9	2.3	0.068	7.01	0.2	<10
25/07/2012	ADP003	7.46	13.5	11.8	2.9	1.1	0.35	4.74	0.384	10
01/08/2012	ADP003	7.41	17.5	15.8	4.2	1.5	0.54	2.97	0.103	20
08/08/2012	ADP003	7.1	2.5	1.4	3.1	3.1	0.17	3.31	0.428	10
15/08/2012	ADP003	7.56	2	1.8	1.7	<0.5	0.18	5.19	0.553	<10
22/08/2012	ADP003	7.65	47	45.8	6.9	22.2	1.01	5.54	0.252	<10
29/08/2012	ADP003	7.54	4	3.2	2.4	4.3	0.27	3.57	0.811	50
05/09/2012	ADP003	7.46	4.5	4.3	3.1	<0.5	0.54	4.81	0.804	20
12/09/2012	ADP003	7.56	1	0.5	2.9	2.9	0.32	4.24	0.873	10
19/09/2012	ADP003	7.54	2.5	2.1	5.9	3.2	0.3	4.02	1.004	10
26/09/2012	ADP003	7.52	2.5	2.2	2.1	4.7	0.9	5.13	0.469	<10
03/10/2012	ADP003	7.44	4.5	3.4	1.2	3.5	0.23	5.06	0.069	40
10/10/2012	ADP003	7.65	<0.5	<0.5	1.3	1.2	0.25	4.34	0.875	130
17/10/2012	ADP003	7.5	5	4.7	1.5	3.5	0.38	4.55	0.509	720
24/10/2012	ADP003	7.57	6.5	5.9	1.7	<0.5	0.36	5.3	0.857	10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
31/10/2012	ADP003	7.44	4	3.6	2.5	11.9	0.73	6.29	1.641	40
07/11/2012	ADP003	7.29	<0.5	<0.5	1.9	0.6	0.52	4.4	1.338	20
14/11/2012	ADP003	7.39	19	18.6	9.2	1.5	1.37	5.89	0.649	10
21/11/2012	ADP003	7.23	3.5	3.3	1	2	0.2	7.25	0.334	50
28/11/2012	NOTE: ADP001	7.53	1	<0.5	2	5.1	0.07	3.23	0.195	47000
05/12/2012	ADP003	7.52	2	1.5	1.3	23.6	0.19	3.51	0.416	30
12/12/2012	ADP003	7.55	0.5	<0.5	0.9	4.5	0.12	4.66	0.828	10
19/12/2012	ADP003	7.53	14	13.4	2.1	1	0.52	4.3	0.711	10
26/12/2012	ADP003	7.35	15	14.5	3.2	1.1	0.59	4.76	0.514	<10
02/01/2013	ADP003	7.37	3	2.8	1.1	1.3	0.15	3.17	0.029	10
09/01/2013	ADP003	7.46	1.5	1.2	3.1	2	0.12	3.05	0.238	54000
16/01/2013	NOTE: ADP001	7.39	1	0.5	4.2	<0.5	0.31	4.1	1.349	90000
23/01/2013	NOTE: ADP001	7.22	<0.5	<0.5	4.7	5.1	0.09	3.95	0.092	14000
30/01/2013	NOTE: ADP001	7.12	2	1.8	1.7	1.8	0.19	3.72	0.179	36000
06/02/2013	ADP003	7.58	1	0.7	1.1	2	0.13	7.42	0.473	<10
13/02/2013	ADP003	7.59	2.5	2.2	1.3	<0.5	0.19	5.35	0.4	<10
20/02/2013	ADP003	7.26	1.5	1.3	1.1	0.8	0.24	3.14	0.505	<10
27/02/2013	ADP003	7.28	2.5	2.3	5.1	3.7	0.39	5.79	2.29	550
06/03/2013	ADP003	7.08	<0.5	<0.5	2.3	2.4	0.77	6.09	0.284	9000
13/03/2013	ADP003	7.41	1.5	0.7	1.4	1.8	0.2	5.2	0.357	20
20/03/2013	ADP003	7.45	6	5.1	1.4	1.6	0.23	5.4	0.266	<10
27/03/2013	ADP003	7.55	3	2.2	3	3.9	0.15	3.81	0.281	60
03/04/2013	ADP003	7.45	1	0.2	0.8	<0.5	0.22	4.86	0.706	10
10/04/2013	ADP003	7.51	2.5	1.7	1	<0.5	0.26	5.07	0.443	220
17/04/2013	ADP003	7.26	7	6.2	1.9	3.1	0.52	8.96	0.899	10
24/04/2013	ADP003	7.4	<0.5	<0.5	1.3	1.4	0.12	5.23	0.167	170
01/05/2013	ADP003	7.17	2	1.4	0.9	<0.5	0.16	5.13	0.374	10
08/05/2013	ADP003	7.64	1	<0.5	1.8	5.6	0.29	6.66	1.02	40
15/05/2013	ADP003	7.74	0.5	<0.5	0.7	1.4	0.41	4.02	0.366	<10
22/05/2013	ADP003	7.47	0.5	<0.5	1.1	3	0.52	6.28	1.188	<10
29/05/2013	ADP003	7.52	2	1.2	1	1.8	0.33	5.42	0.577	<10
05/06/2013	ADP003	7.6	2	1.5	1.3	<0.5	0.79	5.47	0.355	10
12/06/2013	ADP003	7.32	2.5	2	1.5	1.6	0.81	3.67	0.593	<10
19/06/2013	ADP003	7.22	3	2.8	1.7	<0.5	0.43	5.73	0.725	<10
26/06/2013	ADP003	7.34	2.5	1.9	1.3	4.7	0.17	5	0.587	<10
03/07/2013	ADP003	6.79	2	1.3	4.6	2.7	0.26	2.96	0.039	14000
10/07/2013	ADP003	7.49	1	<0.5	1.1	<0.5	0.26	7.3	0.517	10
17/07/2013	ADP003	7.54	1	<0.5	0.9	0.6	0.13	5.45	0.3	<10
24/07/2013	ADP003	7.46	7	5.1	1.4	2.4	0.18	6.83	0.885	<10
31/07/2013	ADP003	7.48	2.5	2	1.2	0.9	0.15	5.08	0.619	<10
07/08/2013	ADP003	7.68	3	2.4	0.9	0.9	0.14	4.61	0.39	<10
14/08/2013	ADP003	7.44	4.5	3.7	1.6	<0.5	0.31	4.96	0.62	<10
21/08/2013	ADP003	7.48	3	2.8	0.7	3	0.2	5.59	0.321	<10
28/08/2013	ADP003	7.29	3	2.6	2.5	1	0.07	4.04	0.015	27000
04/09/2013	ADP003	7.36	1	0.6	0.8	3.9	0.16	5.52	0.639	10
11/09/2013	ADP003	7.41	1.5	1.2	2.6	2.3	0.28	3.95	0.751	<10
18/09/2013	ADP003	7.2	8	7.7	3.3	2	0.47	2.14	0.272	10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
25/09/2013	ADP003	7.49	10.5	10.3	2.9	<0.5	0.35	3.98	0.351	10
02/10/2013	ADP003	7.09	2.5	2.3	1.5	1	0.239	3.985	0.282	<10
09/10/2013	ADP001	7.13	1	0.9	0.9	0.8	0.05	2.99	0.365	10000
16/10/2013	ADP001	7.3	2.5	2.3	0.8	<0.5	0.04	3	0.034	10500
23/10/2013	ADP003	7.27	1	0.99	1.9	5.1	0.12	3.57	0.409	20000
30/10/2013	ADP003	7.53	2.5	2.3	1	1.2	0.16	3.97	0.126	<10
06/11/2013	ADP003	7.19	12.5	12	2.4	1	0.55	3.49	0.013	20
13/11/2013	ID TANK	7.07	1.5	1.3	4.1	1.9	0.24	6.56	1.217	36000
20/11/2013	ADP003	7.3	<0.5	<0.5	0.9	0.8	0.25	4.37	0.783	<10
27/11/2013	ADP003	7.31	1	0.5	0.9	0.9	0.22	5.3	0.278	<10
04/12/2013	ADP003	7.37	2.5	1.8	0.9	1.4	0.43	4.53	0.324	<10
11/12/2013	ADP003	7.42	<0.5	<0.5	0.7	2.6	0.25	5.16	0.356	<10
18/12/2013	ADP003	7.45	1	0.7	0.9	1.3	0.18	5.12	0.229	10
24/12/2013	ADP003	7.31	2	1	1.3	<0.5	0.233	4.833	0.256	<10
02/01/2014	ADP003	7.15	<0.5	<0.5	0.8	1.6	0.465	4.814	0.575	<10
08/01/2014	ADP003	7.51	2	1.1	1	<0.5	0.523	4.875	0.386	30
15/01/2014	ADP003	7.41	1.5	0.9	0.7	2.4	0.71	4.59	0.288	<10
22/01/2014	ADP003	7.56	<0.5	<0.5	1.3	1	0.6	4.66	0.436	<10
29/01/2014	ADP003	7.48	6	4.5	2.2	1	1.17	4.98	0.898	<10
05/02/2014	ADP003	7.19	2.5	1.8	1.1	1.5	0.52	5.4	0.364	<10
12/02/2014	ADP003	7.5	4.5	3.7	1.3	<0.5	0.3	4.66	0.433	10
19/02/2014	ADP003	7.39	4	3.6	1.2	2.9	0.24	4.7	0.192	<10
26/02/2014	ADP003	7.42	1.5	1	0.9	<0.5	0.2	4.78	0.255	<10
05/03/2014	ADP003	7.21	<0.5	<0.5	1.2	<0.5	0.21	4.85	0.216	<10
12/03/2014	ADP003	7.59	4	3.1	0.95	<0.5	0.19	4.16	0.135	<10
19/03/2014	ADP003	7.23	<0.5	<0.5	1.3	0.6	0.17	4.22	0.225	<10
26/03/2014	ADP003	7.24	1	<0.5	1.7	0.7	0.2	6.87	0.88	10
02/04/2014	ADP003	7.08	<0.5	<0.5	0.87	9.7	1.03	7.46	0.776	<10
09/04/2014	ADP003	7.44	1	<0.5	1	3.4	0.12	4.65	0.346	<10
16/04/2014	ADP003	7.28	<0.5	<0.5	0.7	4.7	0.1	5.58	0.332	<10
23/04/2014	ADP003	7.48	1.5	1.1	1.3	1.4	0.13	6.01	0.482	10
30/04/2014	ADP003	7.08	0.5	<0.5	1.2	2.8	0.11	6.11	0.541	20
07/05/2014	ADP003	7.13	0.5	<0.5	0.8	4.3	0.09	6.52	0.625	10
14/05/2014	ADP003	7.01	<0.5	<0.5	1.1	2.7	0.11	5.47	0.402	<10
21/05/2014	ADP003	7.14	1	<0.5	0.8	3.1	0.19	5.05	0.236	<10
28/05/2014	ADP003	6.94	1.5	<0.5	1.9	<0.5	0.55	3.58	0.889	<10
04/06/2014	ADP003	7.09	2.5	1.5	1.6	1.6	0.15	3.81	0.482	<10
11/06/2014	ADP003	6.97	0.5	<0.5	1.7	<0.5	0.18	3.79	0.371	<10
18/06/2014	ADP003	6.89	2.5	1.5	1.2	3.8	0.31	5.321	0.378	<10
25/06/2014	ADP003	6.56	2.5	2.2	1.5	<0.5	0.72	4.34	0.426	<10
02/07/2014	ADP003	7.12	3	2.4	1	1.6	0.866	5.45	0.041	<10
09/07/2014	ADP003	7.38	5.5	5.2	1.9	0.9	0.26	6.08	0.292	<10
16/07/2014	ADP003	7.19	2	1.5	1.9	<0.5	0.4	5.75	0.981	530
23/07/2014	ADP003	7.42	<0.5	<0.5	2.6	4.9	0.5	4.83	0.526	<10
30/07/2014	ADP003	7.42	4.5	3.9	2.7	1.6	1.06	3.28	1.345	<10
06/08/2014	ADP003	7.03	0.5	<0.5	1.5	<0.5	0.16	2.33	0.054	18000
13/08/2014	ADP003	7.23	<0.5	<0.5	1.4	5.8	1.18	5.68	0.789	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
20/08/2014	ADP003	6.99	5	4.7	1.9	1.4	0.83	5.11	0.384	<10
27/08/2014	ADP003	6.45	<0.5	<0.5	1.2	1.4	0.95	3.53	0.05	36000
03/09/2014	ADP003	6.86	4	3.5	5.6	<0.5	1.04	8.55	1.776	3600
10/09/2014	ADP003	6.93	<0.5	0	1.4	1.5	0.42	8.53	0.75	180
17/09/2014	ADP003	7.2	1.5	1.3	1.7	3	0.52	7.33	1	70
24/09/2014	ADP003	7.05	1.5	1.3	2.8	0.6	0.658	6.58	0.921	<10
01/10/2014	ADP003	7.01	1.5	1.3	2.3	<0.5	0.75	5.97	0.678	100
08/10/2014	ADP003	7.32	3	2.6	1.4	2.8	1.15	5.11	0.457	10
15/10/2014	ADP003	7.15	0.5	<0.5	1.3	3.5	2.12	5.29	0.055	18000
22/10/2014	ADP003	8.02	6.5	5.9	2.4	3.2	0.43	7.14	0.222	<10
29/10/2014	ADP003	7.05	2	1.8	1	<0.5	1.33	5.56	0.073	18000
05/11/2014	ADP003	7.64	<0.5	<0.5	1.1	3.5	0.49	4.24	0.212	6500
12/11/2014	ADP003	7.92	1.5	<0.5	1.1	<0.5	0.87	6.35	0.476	<10
19/11/2014	ADP003	8.01	3	2.2	2.4	1.4	0.83	5.33	0.379	<10
26/11/2014	ADP003	7.92	8.5	4.8	2.2	3.5	1.21	2.82	0.395	20
03/12/2014	ADP003	7.61	0.5	<0.5	3.9	<0.5	0.75	5.01	0.555	54000
10/12/2014	ADP003	7.67	5.5	5	3.7	4.6	0.97	4.22	0.394	9000
17/12/2014	ADP003	7.72	9	8.5	1.7	1.8	1.91	4.93	0.615	10
24/12/2014	ADP003	7.51	0.5	0	1.6	1.9	0.93	6.99	0.865	<10
31/12/2014	ADP003	7.03	1.5	0.9	1.2	1.1	1.552	7.11	0.682	<10
07/01/2015	ADP003	7.68	<0.5	<0.5	2.2	3.8	1.4	7.46	1.006	108000
14/01/2015	ADP003	7.68	4	3.1	1.6	0.7	0.73	5.58	0.315	120
21/01/2015	ADP003	7.61	3	2	1.7	2.3	0.41	7.31	0.394	3600
28/01/2015	ADP003	7.46	8	6.1	3.3	2.5	1.21	6.4	1.293	40
04/02/2015	ADP003	7.51	3	2.3	2.4	1.9	0.24	3.84	0.625	5000
11/02/2015	ADP003	7.67	4.5	2.1	1.9	5.1	0.72	4.29	1.943	150
18/02/2015	ADP003	7.65	3	2.6	1.5	0.9	0.58	5.51	0.593	220
25/02/2015	ADP003	7.58	8.5	7.9	4.5	3.4	0.37	7.69	1.194	9000
04/03/2015	ADP003	7.63	1	<0.5	1.9	6.4	0.71	12.82	1.897	10
11/03/2015	ADP003	7.64	<0.5	<0.5	1.6	2.8	0.44	5.34	0.641	30
18/03/2015	ADP003	7.6	3	1.8	1.6	3.4	0.56	7.46	0.782	20
25/03/2015	ADP003	7.67	7.5	6.2	2.2	1.6	1.24	4.471	0.366	200
01/04/2015	ADP003	7.56	2	1.1	1.9	3.6	0.71	4.66	0.904	460
08/04/2015	ADP003	7.4	0.5	<0.5	1.1	2.2	0.59	7.14	0.495	30
15/04/2015	ADP003	7.53	1.5	1	1.2	<0.5	0.44	7.41	0.278	<10
22/04/2015	ADP003	7.54	<0.5	<0.5	1	3	0.61	7.99	0.971	20
29/04/2015	ADP003	7.34	3	2.2	1.6	<0.5	0.34	4.56	0.357	20
06/05/2015	ADP003	7.49	2	0.5	3.4	1.3	0.58	5.78	0.608	400
13/05/2015	ADP003	7.58	1	0.6	1.8	1.4	0.37	7.32	1.118	5400
20/05/2015	ADP003	7.59	3	1.9	1.1	2.7	0.28	9.99	0.552	10
27/05/2015	ADP003	7.56	<0.5	<0.5	2.2	1	0.35	5.03	0.037	500
03/06/2015	ADP003	7.55	<0.5	<0.5	0.86	3.7	0.05	4.65	0.05	5400
10/06/2015	ADP003	7.68	1.5	1.3	1.6	<0.5	0.41	5.92	0.346	60
17/06/2015	ADP003	7.66	3.5	3	1.8	1.4	0.74	5.43	0.683	540
24/06/2015	ADP003	7.65	1.5	0.8	1.9	2.2	0.213	6.312	0.368	270
01/07/2015	ADP003	7.61	2	1.8	2	2	0.9	6.25	0.449	240
08/07/2015	ADP003	7.59	1	<0.5	2.1	<0.5	1.35	6.59	0.297	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
15/07/2015	ADP003	7.59	0.5	<0.5	1.5	3.1	0.43	8.47	0.96	<10
22/07/2015	ADP003	7.53	2	<0.5	2.3	4	0.37	7.99	0.861	<10
29/07/2015	ADP003	7.48	1	<0.5	1.5	2.8	0.61	7.77	1.302	<10
05/08/2015	ADP003	7.47	5	3.6	2.9	2.1	0.57	7.58	1.152	<10
12/08/2015	ADP003	7.63	1.5	<0.5	2.2	<0.5	0.39	7.37	1.065	10
19/08/2015	ADP003	7.75	1.5	1	1.7	8	0.37	6.12	1.061	10
26/08/2015	ADP003	7.58	5.5	4.6	2.2	1.2	0.43	3.81	0.606	<10
02/09/2015	ADP003	7.5	2	1.4	1.8	2.4	0.72	7.16	0.981	<10
09/09/2015	ADP003	7.22	0.5	<0.5	1.58	1.5	0.71	6.82	0.729	10
16/09/2015	ADP003	7.65	5	4.3	1.8	5.3	0.7	5.65	0.326	10
23/09/2015	ADP003	7.47	1	0.7	1.2	2.6	0.59	4.73	0.384	<10
30/09/2015	ADP003	7.51	<0.5	<0.5	2.2	<0.5	0.51	4.97	0.439	<10
07/10/2015	ADP003	7.57	4.5	3.6	2.2	5.2	0.54	6.63	0.374	<10
14/10/2015	ADP003	7.62	6	2.8	3	1.8	0.57	3.68	0.683	<10
21/10/2015	ADP003	7.46	0.5	<0.5	1.6	0.7	0.66	5.43	0.576	<10
28/10/2015	ADP003	6.89	1.5	0.9	3.9	4.5	1.37	5.08	1.618	54000
04/11/2015	ADP003	7.23	1	<0.5	2.1	2	0.26	6.87	0.929	72000
11/11/2015	ADP003	7.5	3.5	1.4	1.4	5	0.75	4.56	0.228	10
18/11/2015	ADP003	7.78	7	2.1	3.1	<0.5	0.31	3.27	0.285	10
25/11/2015	ADP003	7.22	4	3.3	1.4	0.7	0.32	3.21	0.559	<10
02/12/2015	ADP003	7.71	<0.5	<0.5	1.5	<0.5	0.78	3.49	0.956	20
09/12/2015	ADP003	7.63	2	1.7	1	0.7	0.84	4.35	1.082	<10
16/12/2015	ADP003	7.97	4	3.3	2	0.6	0.29	4.64	0.462	<10
23/12/2015	ADP003	7.74	8.7	5.9	7.4	1.1	0.84	2.83	0.572	150
30/12/2015	ADP003	7.53	13	4.3	2.6	5.2	0.854	5.431	0.925	<10
06/01/2016	ADP003	7.47	0.5	0.3	1.4	<0.5	0.883	3.676	0.656	<10
13/01/2016	ADP003	7.59	4	3.2	1	5.1	0.83	4.26	0.442	30
20/01/2016	ADP003	8.11	6	5.6	3.4	3.8	0.57	3.423	0.401	10
27/01/2016	ADP003	7.61	0.5	<0.5	1	<0.5	0.75	4.45	0.943	<10
03/02/2016	ADP003	7.68	6.5	5.2	1.3	3.4	0.961	6.103	0.726	<10
10/02/2016	ADP003	7.66	2	1	0.8	3.4	0.82	5.48	0.597	<10
17/02/2016	ADP003	7.78	2	0.6	1.1	3.1	0.23	5.15	0.251	<10
24/02/2016	ADP003	7.61	3	1.5	1.2	3.3	0.27	3.87	0.288	10
02/03/2016	ADP003	7.22	2	1.2	2.3	2.4	1.21	3.58	0.99	36000
09/03/2016	ADP003	7.25	2.5	1.8	2.4	2.8	0.668	2.43	1.07	54000
16/03/2016	ADP003	7.73	3	2.2	1	<0.5	0.381	4.47	0.809	<10
23/03/2016	ADP003	7.56	1	0.4	1.4	2	0.384	3.78	0.393	20
30/03/2016	ADP003	7.89	5.5	4.9	1.4	1.2	0.343	4.99	0.293	<10
06/04/2016	ADP003	7.68	<0.5	<0.5	1.2	4.6	0.524	4.37	0.988	<10
13/04/2016	ADP003	7.73	3	2.5	0.9	2.1	0.241	4.18	0.391	<10
20/04/2016	ADP003	7.74	2	<0.5	2.1	2.3	0.426	2.97	0.242	10
27/04/2016	ADP003	7.44	2.5	1.8	1.3	0.8	1.3	4.73	0.913	<10
04/05/2016	ADP003	7.49	3.5	2.9	1.2	1.9	0.474	4	0.363	<10
11/05/2016	ADP003	7.5	5	4.7	2	1.9	0.784	4.35	0.779	<10
18/05/2016	ADP003	7.59	1	<0.5	1.4	2.1	0.25	4.82	0.705	<10
28/05/2016	ADP003	7.68	3.5	2.4	7.2	1	0.284	3.42	0.418	54000
01/06/2016	ADP003	7.61	3.5	3.3	1.4	3	0.16	6.12	0.18	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
08/06/2016	ADP003	7.57	2	0.8	2.2	1.2	0.734	7.76	0.633	<10
15/06/2016	ADP003	7.59	5.5	4.2	2.3	1.6	0.223	8.62	0.584	10
22/06/2016	ADP003	7.47	1	<0.5	1.8	<0.5	0.252	5.68	0.703	<10
29/06/2016	ADP003	7.51	<0.5	<0.5	2	2.5	0.298	9.75	1.19	<10
06/07/2016	ADP003	7.64	2.5	1.8	1.1	1.8	0.171	6.53	0.639	<10
13/07/2016	ADP003	7.5	0.5	<0.5	1.2	3	0.268	8.53	0.935	<10
20/07/2016	ADP003	7.64	2	1.2	2.2	0.7	0.225	5.41	0.416	20
27/07/2016	ADP003	7.64	4	1.9	1.4	1.2	0.343	7.36	0.757	70
03/08/2016	ADP003	7.55	4	2.2	1.53	5.2	0.634	6.46	1.03	<10
10/08/2016	ADP003	7.54	1	<0.5	2.2	2.8	0.215	8.7	0.713	<10
17/08/2016	ADP003	7.36	<0.5	<0.5	1.7	<0.5	0.479	7.98	1.13	40
24/08/2016	ADP003	7.49	6.5	5.9	3	6.7	0.415	7.21	1.43	800
31/08/2016	ADP003	7.44	5.5	4.3	2	2.4	0.242	7.8	0.518	300
07/09/2016	ADP003	7.6	4.5	3.8	3	3.8	0.338	5.43	0.435	1080
14/09/2016	ADP003	7.44	1.5	1.4	3	1.9	0.748	8.77	1.39	10
21/09/2016	ADP003	7.53	1.5	<0.5	1.17	4.2	0.18	4.77	0.156	20
28/09/2016	ADP003	7.38	5.5	5	6.57	6.7	0.444	7.07	0.526	230
05/10/2016	ADP003	7.41	1.5	0.8	1	<0.5	0.357	8.76	1.21	<10
12/10/2016	ADP003	7.49	1.5	1.3	1.3	3.4	0.167	6.01	0.475	<10
19/10/2016	ADP003	7.44	1	<0.5	1.9	2.7	0.158	8.26	0.15	330
26/10/2016	ADP003	7.54	4	2	2.5	2.9	0.272	6.08	0.475	110
02/11/2016	ADP003	7.61	4	3	2.6	6.1	0.2	7.51	0.542	60
09/11/2016	ADP003	7.65	7	5.9	1.5	4.6	0.244	7.78	0.391	550
16/11/2016	ADP003	7.48	1.5	<0.5	1.8	2.2	0.325	9.34	0.7	120
23/11/2016	ADP003	7.58	3.5	1.5	1.4	5.6	0.366	8.35	0.487	50
30/11/2016	ADP003	7.73	4.5	3.4	1.7	1.2	0.897	7.39	0.956	600
07/12/2016	ADP003	7.61	0.5	<0.5	1.5	1.5	0.478	4.91	0.436	20
14/12/2016	ADP003	7.78	2.5	1.5	0.9	2.8	0.641	7.28	0.776	<10
21/12/2016	ADP003	7.67	6	5.4	1.2	7.7	0.513	6.81	0.74	50
28/12/2016	ADP003	7.43	1	<0.5	1	<0.5	0.749	7.93	1.211	<10
04/01/2017	ADP003	7.17	4	<0.5	0.7	<0.5	2.352	5.572	0.266	30
11/01/2017	ADP003	7.52	1.5	<0.5	1.1	2.4	0.517	8.112	0.647	30
18/01/2017	ADP003	7.78	<0.5	<0.5	0.6	3.1	0.974	4.69	0.295	40
25/01/2017	ADP003	7.49	<0.5	<0.5	0.9	3	0.168	7	0.33	<10
01/02/2017	ADP003	7.5	2.5	<0.5	0.7	1	0.145	5.12	0.296	<10
08/02/2017	ADP003	7.53	3	<0.5	1.1	4.2	0.195	7.28	0.487	<10
15/02/2017	ADP003	7.5	2	<0.5	1	0.9	0.203	7.46	0.58	<10
22/02/2017	ADP003	7.51	7.5	5.4	0.7	<0.5	0.164	4.52	0.257	10
01/03/2017	ADP003	7.41	0.5	<0.5	1	1.2	0.191	4.52	0.565	<10
08/03/2017	ADP003	7.52	0.5	<0.5	1.1	2.7	0.21	6.73	0.813	<10
15/03/2017	ADP003	7.47	6.5	3.6	1.9	<0.5	0.488	4.04	0.915	400
22/03/2017	ADP003	7.09	1	<0.5	1.1	2.9	1.08	6.69	0.628	<10
29/03/2017	ADP003	7.31	1	<0.5	1.2	0.3	0.736	7.03	0.91	<10
05/04/2017	ADP003	7.26	21.5	20.3	5.5	1.4	0.531	4.84	0.936	50
12/04/2017	ADP003	7.39	1.5	<0.5	2.9	3.2	0.249	8.998	1.234	50
19/04/2017	ADP003	7.41	2	0.7	1.5	3.5	0.146	8.27	0.657	10
26/04/2017	ADP003	7.45	3	<0.5	2.5	1.1	0.228	8.03	0.919	30

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
03/05/2017	ADP003	7.57	2	0.1	2	2.7	0.167	5.31	0.623	<10
10/05/2017	ADP003	7.47	0.5	<0.5	1.6	0.7	0.16	8.62	0.526	<10
17/05/2017	ADP003	7.38	<0.5	<0.5	2.5	<0.5	0.235	9.72	0.776	10
24/05/2017	ADP003	7.59	2	0.3	2	1.4	0.226	7.08	0.515	<10
31/05/2017	ADP003	7.63	0.5	<0.5	1.3	<0.5	0.594	4.54	0.62	<10
07/06/2017	ADP003	7.86	1.5	<0.5	3.2	1.4	0.397	10.2	0.628	<10
14/06/2017	ADP003	6.99	11	8.5	2.7	2.4	1.24	3.6	0.376	<10
21/06/2017	ADP003	7.24	3	0.9	1.7	1.1	0.229	4.15	0.344	<10
28/06/2017	ADP003	7.43	1.5	<0.5	<1.0	<0.5	0.112	6.64	0.374	<10
05/07/2017	ADP003	7.49	2.5	1.6	1.9	1.3	0.346	6.4	4.23	10
12/07/2017	ADP003	7.61	3	<0.5	1.2	1.3	0.159	7.65	0.449	<10
19/07/2017	ADP003	7.65	2	0.7	0.7	0.6	0.279	7.69	0.565	190
26/07/2017	ADP003	7.58	3	1.7	1.4	1	0.189	7.64	0.549	<10
02/08/2017	ADP003	7.52	3	<0.5	1.3	2.8	0.171	8.83	0.815	1030
09/08/2017	ADP003	7.56	2.5	<0.5	1.6	0.8	0.187	8.03	0.534	<10
16/08/2017	ADP003	7.62	3.5	<0.5	2.5	<0.5	0.326	7.37	0.444	990
23/08/2017	ADP003	7.51	10	<0.5	2.7	<0.5	0.46	8.9	1.3	<10
30/08/2017	ADP003	7.67	13.5	<0.5	3.6	2.8	0.553	9.31	0.9	<10
06/09/2017	ADP003	7.59	3.5	0.7	1.4	1.4	0.334	7.54	0.426	<10
13/09/2017	ADP003	7.67	10.5	<0.5	2.9	2.2	0.845	8.12	0.847	<10
20/09/2017	ADP003	7.95	1	<0.5	1	1	0.473	7.11	0.371	10
27/09/2017	ADP003	7.77	5	<0.5	6.1	2.1	0.378	6.79	0.341	<10
04/10/2017	ADP003	7.51	3.5	<0.5	3.3	<0.5	0.57	5.95	0.467	10
11/10/2017	ADP003	7.6	3.5	2	1.3	0.9	1.04	6.41	0.345	<10
18/10/2017	ADP003	7.17	2.5	<0.5	2.2	2.4	0.522	4.28	0.023	60
25/10/2017	ADP003	7.16	2.5	<0.5	1.6	<0.5	0.322	7.46	0.648	10
01/11/2017	ADP003	7.62	4.5	<0.5	2.7	1	0.251	8.8	0.275	260
08/11/2017	ADP003	7.54	4	<0.5	2.1	1	0.202	7.59	0.616	240
15/11/2017	ADP003	7.7	4.5	<0.5	1.6	2.9	0.195	7.81	0.342	10
22/11/2017	ADP003	7.55	4.5	<0.5	1.7	1.6	0.154	8.35	0.328	<10
29/11/2017	ADP003	7.51	1.5	<0.5	5.5	1.7	0.338	6.89	1.04	10
06/12/2017	ADP003	7.53	3.5	1.3	0.8	1.2	0.171	4.99	0.515	370
13/12/2017	ADP003	7.6	4	<0.5	1.2	2	0.199	6.07	0.312	<10
20/12/2017	ADP003	7.63	1	<0.5	1.7	3.4	0.302	5.34	0.491	<10
27/12/2017	ADP003	7.69	1	<0.5	1.4	8.3	0.269	4.428	0.648	<10
03/01/2018	ADP003	7.51	2	<0.5	0.7	2.6	0.588	2.221	0.256	<10
10/01/2018	ADP003	7.78	3	<0.5	1.3	<0.5	0.486	5.977	0.451	340
17/01/2018	ADP003	7.75	4	3.1	1.4	5.5	0.242	5.61	0.005	30
24/01/2018	ADP003	7.74	3	0.8	3	4.8	0.477	6.43	0.393	70
31/01/2018	ADP003	7.64	1.5	<0.5	1.2	1	0.54	6.24	4.388	<10
07/02/2018	ADP003	7.59	1.5	<0.5	1	2.2	0.342	4.82	0.275	150
14/02/2018	ADP003	6.98	2.5	<0.5	1.5	4.7	0.601	6.19	0.277	<10
21/02/2018	ADP003	7.81	2.5	<0.5	2.1	4	0.525	2.75	0.283	20
28/02/2018	ADP003	7.46	1.5	0.5	<1	0.8	0.533	4.92	0.788	<10
08/03/2018	ADP003	7.35	4.5	2.5	1.4	3.6	0.77	2.93	0.374	<10
15/03/2018	ADP003	7.62	8	4.7	1.1	<0.5	0.462	5.62	0.336	140
22/03/2018	ADP003	7.75	5.5	<0.5	1.2	5.8	0.273	10.4	0.444	300

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
29/03/2018	ADP003	7.54	2	1	0.6	<0.5	0.509	6.76	0.773	<10
05/04/2018	ADP003	7.59	3	1.9	1	0.8	0.373	8.02	0.78	10
12/04/2018	ADP003	7.73	1.5	<0.5	1.1	0.9	0.275	9.96	0.778	<10
19/04/2018	ADP003	7.7	1	<0.5	1	1.5	0.168	5.3	0.566	<10
26/04/2018	ADP003	7.62	1	<0.5	2.1	0.9	0.404	7.05	0.689	<10
03/05/2018	ADP003	7.65	7.5	5.8	1.2	1.3	0.44	8.63	1.04	10
10/05/2018	ADP003	7.66	3	<0.5	1.6	2.6	0.473	11	1.08	<10
17/05/2018	ADP003	7.76	1.5	0.2	1.2	3	0.205	6.38	0.436	<10
24/05/2018	ADP003	7.73	0.5	<0.5	5.6	4.7	0.267	7.65	0.784	<10
31/05/2018	ADP003	7.64	5.5	4.2	4.1	0.6	0.274	4.19	0.261	<10
07/06/2018	ADP003	7.63	6.5	4	3	2.5	0.457	6	1.34	5400
14/06/2018	ADP003	7.71	1.5	0.3	1.7	2.6	0.206	7.55	0.475	<10
21/06/2018	ADP003	7.69	2.5	<0.5	2.2	0.5	0.329	8.24	0.411	980
28/06/2018	ADP003	7.75	4.5	2.2	1.7	1.6	0.702	13.1	0.343	70
05/07/2018	ADP003	7.56	2.5	<0.5	1.6	1.9	0.368	6.84	0.762	10
12/07/2018	ADP003	7.71	6.5	0.5	2	0.5	0.356	8.43	0.397	10
19/07/2018	ADP003	7.57	2	0.7	1.62	1.2	0.286	9.02	0.476	10
26/07/2018	ADP003	7.64	11.5	9.9	4.2	1.2	0.465	7.51	0.437	40
02/08/2018	ADP003	7.67	14.5	11	4.9	3.4	0.557	10.3	0.437	180
09/08/2018	ADP003	7.71	3.8	2.3	3.5	5.1	0.349	8.76	0.444	410
16/08/2018	ADP003	7.7	0.5	0.3	1	1.2	0.306	8.31	0.612	<10
23/08/2018	ADP003	7.69	4.5	3.9	2.1	3.2	1.05	5.72	1.42	<10
30/08/2018	ADP003	7.56	0.5	0.3	0.9	1.8	0.729	7.08	1.12	<10
06/09/2018	ADP003	7.54	2.5	1.9	0.9	2.9	0.211	3.88	0.431	10
13/09/2018	ADP003	7.57	3	0.4	1.9	5.3	0.356	4.26	0.488	<10
20/09/2018	ADP003	7.66	2	<0.5	2	2	0.444	6.01	1.41	130
27/09/2018	ADP003	7.69	5.5	0.4	3.6	1.7	0.757	9.8	1.44	80
04/10/2018	ADP003	7.58	2.5	1.2	1	1.5	0.191	4.89	0.404	<10
11/10/2018	ADP003	7.29	20	18.3	3.2	3.1	0.212	2.72	1.16	13800
18/10/2018	ADP003	7.34	8	6.3	2.7	2.2	0.606	3.06	0.373	40
25/10/2018	ADP003	7.61	5.5	1.8	1.2	<0.5	0.216	4.92	0.353	70
01/11/2018	ADP003	7.54	5.5	<0.5	1.8	13.1	0.186	5.36	0.328	800
08/11/2018	ADP003	7.61	3	0.3	1.1	12	0.192	7.07	0.68	<10
15/11/2018	ADP003	7.63	1.5	<0.5	1.2	<0.5	0.15	6.5	0.564	<10
22/11/2018	ADP003	7.7	6	3.3	1.5	0.9	0.18	5.76	0.38	120
29/11/2018	ADP003	7.71	8	1.3	2.2	1.1	0.21	8.08	0.545	700
06/12/2018	ADP003	7.71	4.5	<0.5	1.7	<0.5	0.192	7.12	0.342	310
13/12/2018	ADP003	7.67	4	1.8	3.1	3.3	0.21	8.36	0.449	1650
21/12/2018	ADP003	7.78	3.5	2.2	2.3	<0.5	0.313	7.68	0.526	<10
27/12/2018	ADP003	6.93	25	3.1	6.1	2.2	0.817	8.94	0.985	80
03/01/2019	ADP003	7.66	3	2.2	1.9	1.9	0.74	8.17	1.08	10
10/01/2019	ADP003	7.67	0.5	<0.5	1.2	<0.5	0.837	8.04	1.321	<10
17/01/2019	ADP003	7.76	0.5	<0.5	1.4	1	0.621	5.52	0.933	30
24/01/2019	ADP003	7.74	<0.5	<0.5	2.7	<0.5	0.647	6.13	0.774	120
31/01/2019	ADP003	8.26	<0.5	<0.5	1.5	0.7	0.731	8.37	1.583	20
07/02/2019	ADP003	7.76	3.3	2	1.4	<0.5	0.669	5.34	0.91	20
14/02/2019	ADP003	8	5.3	2.8	1	0.6	0.588	5.6	0.793	20

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
21/02/2019	ADP003	7.82	5	2.9	3.3	1.2	0.633	6.06	0.738	310
28/02/2019	ADP003	7.93	8.5	4.1	2.1	<0.5	0.821	6.2	0.821	400
07/03/2019	ADP003	7.77	<0.5	<0.5	2.1	1.1	0.813	7.232	1.04	800
14/03/2019	ADP003	7.89	5.3	2.6	5.4	<0.5	2.73	16.4	11.43	108000
21/03/2019	ADP003	7.57	4	<0.5	5.8	6.3	3.78	9.43	4.609	36000
28/03/2019	ADP003	7.59	1.5	1.1	1.5	1.2	0.344	6.22	1.063	700
04/04/2019	ADP003	7.52	1.5	0.9	3.3	0.8	0.775	4.68	1.35	500
11/04/2019	ADP003	7.78	1	<0.5	2.1	1.7	1.04	7.28	1.48	80
18/04/2019	ADP003	7.54	<0.5	<0.5	1.5	1.8	0.651	11.4	2.08	20
24/04/2019	ADP003	7.48	0.5	<0.5	1.9	4.8	0.762	9.52	2.07	90
02/05/2019	ADP003	7.77	4	3.2	2.6	0.8	0.414	7.88	0.808	3400
08/05/2019	ADP003	7.66	1	<0.5	1.3	1	0.59	7.98	1.57	80
15/05/2019	ADP003	7.57	0.7	0.2	1.9	<0.5	0.319	6.21	0.797	900
22/05/2019	ADP003	7.48	1.5	0.8	1.8	1.3	0.644	9	1.77	<10
29/05/2019	ADP003	7.73	3.3	2.7	1.7	2	0.449	6.56	2.96	1400
05/06/2019	ADP003	7.6	15	4.4	5.4	<0.5	0.68	6.63	1.84	10
12/06/2019	ADP003	7.76	2	0.9	3.5	1.9	0.598	8.24	6.96	100
19/06/2019	ADP003	7.61	2	1.1	1.1	1.4	0.241	5.57	0.727	<10
26/06/2019	ADP003	7.23	10.5	8.9	4.8	1.1	0.393	4.38	0.98	480
03/07/2019	ADP003	7.51	<0.5	<0.5	2.4	2.6	0.415	7.87	2.36	<10
10/07/2019	ADP003	7.58	1.5	0.5	2.3	<0.5	0.572	9.01	4.37	<10
17/07/2019	ADP003	7.7	5	4.6	2.2	2	0.299	9.18	1.07	90
24/07/2019	ADP003	7.69	0.5	0.4	2.7	<0.5	0.633	10.1	4.27	50
31/07/2019	ADP003	7.81	24	16.4	8.5	2.2	0.816	18	12.4	120
07/08/2019	ADP003	7.54	3.3	2.8	2.1	<0.5	0.519	6.81	2.24	<10
14/08/2019	ADP003	7.61	6	5.4	2.2	<0.5	0.323	5.5	0.704	<10
21/08/2019	ADP003	7.52	2	0.9	3.5	2	1.02	9.89	4.64	700
28/08/2019	ADP003	7.72	4.7	3.3	2.2	0.7	0.247	8.36	0.769	<10
04/09/2019	ADP003	7.66	2	1.3	2.9	2.4	0.491	7.92	1.81	<10
11/09/2019	ADP003	7.6	<0.5	<0.5	2.1	1.9	0.448	8.95	1.55	<10
18/09/2019	ADP003	7.56	3	0.8	3.9	8.4	0.425	10.3	1.61	<10
25/09/2019	ADP003	7.77	1	<0.5	3.2	3.4	0.637	10.1	0.709	150
02/10/2019	ADP003	7.53	3.3	0.6	4.5	2.1	0.469	9.36	1.1	<10
09/10/2019	ADP003	7.45	5	4.5	2.3	5.5	0.202	6.55	0.046	5300
16/10/2019	ADP003	7.44	<0.5	<0.5	3.9	0.7	0.104	7.16	0.091	19000
23/10/2019	ADP003	7.86	22.5	6.8	12	0.8	1.25	7.74	0.646	160
30/10/2019	ADP003	7.7	2.5	2	1.7	0.8	0.652	8.55	1.48	10
06/11/2019	ADP003	7.82	5	<0.5	2.2	1.1	0.389	6.72	0.623	70
13/11/2019	ADP003	7.73	1	<0.5	2.2	0.5	0.65	8.27	1.28	<10
21/11/2019	ADP003	7.91	1.5	<0.5	3.2	2.2	1.44	7.39	1.75	<10
27/11/2019	ADP003	7.76	5	3.6	2.6	3.8	0.415	7.54	0.775	<10
04/12/2019	ADP003	7.51	5	3.5	1.5	3.1	0.311	7.05	0.666	<10
11/12/2019	ADP003	7.83	8	2.2	2.8	1.4	1.16	6.96	1.167	20
18/12/2019	ADP003	7.6	8.5	0.4	0.7	2.6	0.534	6.21	0.693	20
24/12/2019	ADP003	7.59	3.5	2.6	2.5	2.7	0.567	6.32	0.84	<10
02/01/2020	ADP003	7.7	4	<0.5	1.3	0.3	0.947	4.31	0.848	<10
08/01/2020	ADP003	7.57	5	4.4	1.6	1.2	0.821	6.49	0.898	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
15/01/2020	ADP003	7.55	4	2.2	1.2	3	0.541	7.4	0.92	20
22/01/2020	ADP003	7.4	4	0.4	1.4	2.3	0.545	5.84	0.562	<10
29/01/2020	ADP003	7.48	2.5	<0.5	0.5	3.2	0.454	6.14	0.64	<10
05/02/2020	ADP003	7.48	0.5	<0.5	1.4	1.1	0.655	7.01	1.49	20
12/02/2020	ADP003	7.41	3	2.6	1.1	3.9	0.836	5.7	0.85	150
19/02/2020	ADP003	7.35	0.5	0.3	1.3	2.4	0.699	8.31	1.33	10
26/02/2020	ADP003	7.41	0.5	0.2	2.5	2.6	0.643	4.99	1.16	<10
04/03/2020	ADP003	7.65	4	1.4	2.2	2.8	0.591	10.1	1	2400
11/03/2020	ADP003	7.46	2	<0.5	0.9	5.4	0.394	4.87	0.574	60
18/03/2020	ADP003	7.47	<0.5	<0.5	1	3	0.659	8.78	1.19	80
25/03/2020	ADP003	7.55	1.5	0.5	1.1	2.1	0.45	7.62	0.761	410
01/04/2020	ADP003	7.52	4	2.5	1.2	4.8	0.487	9.3	1.1	560
08/04/2020	ADP003	7.64	<0.5	<0.5	2	2	1.06	9.84	2.37	<10
15/04/2020	ADP003	7.68	3	0.8	1.6	2.3	0.655	7.65	0.99	<10
22/04/2020	ADP003	7.75	0.7	<0.5	1.9	3.3	0.864	9.57	1.85	<10
29/04/2020	ADP003	7.51	1	0.4	1.7	1.1	0.532	8.37	1.52	<10
06/05/2020	ADP003	7	7	0.9	3.5	4.8	0.542	9.17	1.47	190
13/05/2020	ADP003	7.71	8	<0.5	2.8	2.4	0.716	10.3	1.48	820
20/05/2020	ADP003	7.74	3	1.4	2.5	1.8	0.616	8.63	2.42	<10
27/05/2020	ADP003	7.6	6.7	4.4	2	3.5	0.284	8.46	0.62	30
03/06/2020	ADP003	7.61	3	0.8	1.8	0.9	0.37	7.18	0.741	<10
10/06/2020	ADP003	7.69	3	1.6	2.1	1	0.39	8.41	1.09	10
17/06/2020	ADP003	7.49	3	1.2	1.7	6.3	0.69	10.3	1.805	<10
24/06/2020	ADP003	7.5	3	2	2.8	3.9	0.37	7.41	1.07	10
01/07/2020	ADP003	7.56	2	0.8	1.6	4.8	0.54	7.6	1.24	20
08/07/2020	ADP003	7.55	4	3	1.5	0.5	0.82	9.17	2.62	<10
15/07/2020	ADP003	7.63	3	2.1	3.7	1.7	0.435	9.11	0.889	650
22/07/2020	ADP003	7.06	5	3.4	4	1.7	0.509	6.67	0.809	140
29/07/2020	ADP003	7.53	2	1.4	2.3	1.7	0.43	7.11	1.71	<10
05/08/2020	ADP003	7.72	13	<0.5	10	8.8	1.86	11.6	4.89	510
12/08/2020	ADP003	7.65	5	3.5	5.3	0.8	0.86	14	7.94	280
19/08/2020	ADP003	7.58	6	4.8	6.6	1	0.524	8.25	0.808	220
26/08/2020	ADP003	7.6	10	8.6	8.7	5.2	0.74	11.1	1.19	90
02/09/2020	ADP003	7.57	4	2.5	7.1	10.4	0.738	8.95	1.23	260
09/09/2020	ADP003	7.55	3	2	4.3	1.6	1	9.84	3.81	<10
16/09/2020	ADP003	7.72	10	3.3	1.2	5.6	1.12	8.76	1.72	840
23/09/2020	ADP003	7.55	2	0.5	2.2	4	0.55	7.72	1.77	<10
30/09/2020	ADP003	7.65	3	1.3	4.6	4.1	0.46	8.61	1.08	390
07/10/2020	ADP003	7.61	5	3	2.9	3.2	0.576	8.73	1.17	220
14/10/2020	ADP003	7.68	2	1.4	2.4	3.8	0.452	9.89	1.37	<10
21/10/2020	ADP003	7.56	5	2.9	3.4	1.6	1.04	8.34	3.47	190
28/10/2020	ADP003	7.54	5	2.9	5.3	2.3	1.14	6.33	3.44	780
04/11/2020	ADP003	7.88	11	<0.5	3.9	1.5	0.74	8.22	0.999	1600
11/11/2020	ADP003	7.56	1	<0.5	2.2	0	0.77	6.68	2.42	<10
18/11/2020	ADP003	7.73	7	4.7	2	1.2	0.45	5.82	0.797	140
25/11/2020	ADP003	7.84	4	3.3	2.9	3.2	0.527	8.431	1.05	90
02/12/2020	ADP003	7.66	1	0.4	2.4	6.1	0.605	6.65	1.19	10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
09/12/2020	ADP003	7.65	2	<0.5	1.9	2.9	0.625	4.2	0.833	<10
16/12/2020	ADP003	7.07	<1	<1	2.4	1	0.542	2.05	0.8	260
23/12/2020	ADP003	7.48	7	5.5	3.2	-	1.03	7.67	1.83	40
30/12/2020	ADP003	7.33	13	11.3	8.76	-	4.64	9.71	8.06	62400
06/01/2021	ADP003	7.36	3	2.4	1.9	2.7	0.914	4.53	2.27	10
13/01/2021	ADP003	7.36	20	19.1	5.4	<0.5	0.964	6.2	1.09	300
20/01/2021	ADP003	7.5	2	1.6	2.4	1.8	0.812	6.51	2.1	60
27/01/2021	ADP003	7.6	4	3.1	2.5	2.6	0.514	9.58	1.14	10
03/02/2021	ADP003	7.73	<1	<1	2.2	2.1	0.525	8.37	1.23	10
10/02/2021	ADP003	7.74	3	2	2.3	2.8	0.558	9.45	1.54	<10
17/02/2021	ADP003	7.4	5	4.6	3.9	1.4	0.45	5.31	1.72	<10
24/02/2021	ADP003	7.23	9	8.1	10	1.2	4.37	10.1	8.12	420
03/03/2021	ADP003	7.56	8	6.6	2.1	0	0.76	7.29	1.49	110
10/03/2021	ADP003	7.47	2	1.2	2.7	4.2	0.67	7.6	1.69	10
17/03/2021	ADP003	7.36	1	0.4	1.7	0.8	0.431	5.16	1.06	1060
24/03/2021	ADP003	7.17	8	7.7	2.5	7.8	0.615	2.98	0.381	410
31/03/2021	ADP003	7.55	6	4.7	5.2	1	1.83	12.224	7.631	40
07/04/2021	ADP003	7.24	3	0.1	1.2	4	0.228	4.79	0.582	10
14/04/2021	ADP003	7.35	2	<0.5	1.3	9.6	0.325	10.4	1.28	2000
21/04/2021	ADP003	7.46	2	0.4	1.6	6.8	0.443	10.2	2	10
28/04/2021	ADP003	7.68	21	20.4	20.5	1.6	9.6	23.4	21.1	9100
05/05/2021	ADP003	7.52	4	2.4	1.7	0.8	0.361	11.7	2.08	20
12/05/2021	ADP003	7.53	<1	<1	2	6.9	1.439	11.4	2.27	70
19/05/2021	ADP003	7.69	<1	<1	2.1	0.7	0.382	14.2	3.23	<10
26/05/2021	ADP003	7.53	2	1.4	2.9	2.1	0.314	13.6	1.58	1120
02/06/2021	ADP003	7.48	3	2.3	3.1	1	0.415	11.1	1.69	80
09/06/2021	ADP003	7.49	1	0.6	3.7	4	0.44	8.38	1.31	160
16/06/2021	ADP003	7.5	4	2.9	5.3	2	0.275	7.93	0.924	32400
23/06/2021	ADP003	7.64	3	2.3	5.9	<0.5	0.375	6.81	0.911	39000
30/06/2021	ADP003	7.63	3	1.9	3.6	0.9	0.286	7.86	0.975	10
07/07/2021	ADP003	7.41	4	3	4.1	1.9	0.465	15.8	8.28	20
14/07/2021	ADP003	7.67	3	2.2	4.3	<0.5	0.974	12.7	7.57	<10
21/07/2021	ADP003	7.53	1	0.5	2.9	<0.5	-	-	0.708	180
28/07/2021	ADP003	7.69	1	0.4	2.69	<0.5	0.304	14.2	2.1	140
04/08/2021	ADP003	7.48	3	2.3	8.1	1.5	1.08	6.82	1.62	20
11/08/2021	ADP003	7.58	4	3.4	3.6	1	0.465	10.4	1.98	60
18/08/2021	ADP003	7.62	4	1.4	4.2	4.7	0.456	8.66	1.36	3160
25/08/2021	ADP003	7.44	<1	<1	3.6	0.4	0.832	8.1	2.65	40
01/09/2021	ADP003	7.54	5	3.9	2.5	<0.5	0.606	7.02	0.983	390
08/09/2021	ADP003	7.46	2	1.1	2.9	3.1	0.847	7.82	1.968	10
15/09/2021	ADP003	7.45	6	3.7	3.6	1.4	0.782	7.42	2.02	60
22/09/2021	ADP003	7.49	1	<0.5	2.8	4.2	0.826	7.41	1.69	40
29/09/2021	ADP003	7.57	6	1.5	5.9	4.9	0.488	6.76	0.988	1800
06/10/2021	ADP003	7.41	9	6.7	4.5	6.4	0.931	9.33	1.56	10
13/10/2021	ADP003	7.35	2	<0.5	3.8	0.5	0.158	3.74	0.772	5200
20/10/2021	ADP003	7.29	<1	<1	4.2	8.2	0.46	7.31	1.25	70
27/10/2021	ADP003	7.57	7	<0.5	5.3	2.4	0.776	7.99	1.64	790

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
03/11/2021	ADP003	7.55	1	<0.5	4	<0.5	0.441	10.2	1.83	90
10/11/2021	ADP003	7.57	2	0.1	3.2	1.4	0.353	7.4	0.933	2520
17/11/2021	ADP003	7.48	<1	<1	3.6	<0.5	0.752	9.01	3.45	6500
24/11/2021	ADP003	7.55	3	1.7	1.7	2.2	0.301	6.64	0.809	2320
01/12/2021	ADP003	7.34	4	2.3	4	0.6	0.178	3.49	0.849	1240
08/12/2021	ADP003	7.41	3	<0.5	2.9	3	0.428	9.25	3.27	550
15/12/2021	ADP003	7.8	4	<0.5	3.06	1.3	0.316	11.2	1.57	630
22/12/2021	ADP003	7.6	7	5.6	21.4	1.4	0.63	13.1	3.46	2000
29/12/2021	ADP003	7.34	2	1.1	1.8	<0.5	0.275	6.07	1.52	40
05/01/2022	ADP003	7.32	5	3.2	2.8	0.2	0.203	5.06	1.29	1330
12/01/2022	ADP003	7.36	5	3.2	2.08	0.3	0.605	8.69	1.82	70
19/01/2022	ADP003	7.55	2	1.2	1.8	3.2	0.423	9.84	1.36	570
26/01/2022	ADP003	7.46	1	<0.5	1.89	<0.5	0.7	9.22	1.9	50
02/02/2022	ADP003	7.39	1	<0.5	1.7	1.3	0.208	8.99	0.591	20
09/02/2022	ADP003	7.4	3	0.7	2.1	1.2	0.834	6.2	1.25	2410
16/02/2022	ADP003	7.43	5	4.1	4	<0.5	0.395	7.36	1.25	970
23/02/2022	ADP003	7.38	7	5.3	4.3	0.2	1.14	10.5	3.894	50
02/03/2022	ADP003	Data Unavailable Due To Flooding								
09/03/2022	ADP003									
#NAME?	Maturation Pond	7.42	42	<0.5	22.9	2.3	2.63	13.8	10.6	15600
	Maturation Pond	7.5	20	<0.5	13.2	<0.5	3.76	22.2	19.8	20800
	Maturation Pond	7.83	30	22.5	16.6	1.3	1.64	8.98	8.83	23400
	Maturation Pond	7.18	35	<0.5	26.3	<0.5	3.13	20.9	13.7	24700
	Maturation Pond	7.19	60	<0.5	40	6	3.56	23.4	17.8	26000
	Maturation Pond	7.14	55	<0.5	35.5	2.9	3.2	23.2	17.8	20800
	Maturation Pond	7.24	22	<0.5	27.9	2	3.2	24.6	20.6	7800
	IDEA Tank B Clear	7.16	23	21.6	22.9	..	0.426	10.7	6.8	..
	Maturation Pond	7.23	10	7.1	15.3	3.4	3.57	26.3	7.67	2280
	IDEA Tank B Clear	7.08	15	14.5	18	..	0.387	14.5	11.3	..
	Maturation Pond	7.17	50	46.6	17.8	0.6	1.83	15.39	13.7	110
	Maturation Pond	6.99	12	4.9	7.7	2.3	1.06	5.68	4.33	48000
	IDEA Tank B Clear	6.91	7	5.6	8.5	2.1	0.14	3.96	0.85	54000
	Maturation Pond	7.23	3	<0.5	3.4	0.5	1.27	6.35	4.46	3040
	IDEA Tank B Clear	7.23	18	17.3	11.7	1.3	0.459	5.81	<0.005	35200
	Maturation Pond	7.31	5	<0.5	13.9	3.3	1.22	7.28	5.11	7800
	IDEA Tank B Clear	7.26	1	<0.5	7.7	136.6	0.744	5.56	1.48	13000
	Maturation Pond	7.83	19	<0.5	31.2	0.7	1.7	9	3.24	3900
	IDEA Tank B Clear	7.22	4	1.4	12.6	<0.5	0.22	7.8	0.126	14300
	Maturation Pond	7.96	20	<0.5	13.2	0.6	2.83	9.57	4.46	9100
	IDEA Tank B Clear	7.29	22	16.9	18.6	<0.5	0.545	8.14	2.23	16900
	Maturation Pond	7.77	32	<0.5	13	1.6	2.83	9.45	4.77	10400
	IDEA Tank B Clear	7.34	3	<0.5	4.8	1.2	0.137	6.2	0.058	15600

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	Maturation Pond	7.21	14	<0.5	7.9	1.9	1.71	9.499	5.184	32000
	IDEA Tank B Clear	6.91	16	13.2	11.4	0.7	1.108	4.221	2.41	93100
	Maturation Pond	7.83	41	<0.5	11.9	0	2.3	8.09	3.382	5400
	IDEA Tank B Clear	7.29	5	1.9	6	1.9	0.431	5.88	0.796	17600
	Maturation Pond	7.68	35	<0.5	11.5	2.6	2.21	10.5	4.63	3000
	EAST ADP003-TANK	7.18	8	4.6	6.2	1.7	0.605	9.62	1.27	6400
	Maturation Pond	7.2	28	<0.5	16.3	1	2.578	9.039	4.39	9000
	EAST ADP003-TANK	7.15	9	7.3	14.6	0.5	1.456	6.85	1.45	3900
	Maturation Pond	7.64	41	<0.5	14.3	3	1.84	8.81	3.83	900
	EAST ADP003-TANK	7.32	5	3.5	6.6	2	0.678	8.22	1.41	52000
	Maturation Pond	8.07	50	<0.5	16.7	1.4	2.48	10.8	2.95	1640
	EAST ADP003-TANK	7.34	3	1.5	5.5	0.1	0.34	5.83	0.44	11700
	East Mat Pond	7.98	51	<0.5	17.9	1.5	3.21	12.1	4.32	2600
	IDEA B Clear	7.38	5	4	9.1	<0.5	0.34	9.1	0.082	3900
	East Mat Pond	7.49	48	<0.5	5.7	1	3.21	12.1	6.15	6500
	IDEA B Clear	7.47	3	2.1	3.8	<0.5	0.34	9.1	0.021	3900
	East Mat Pond	7.41	22	<0.5	13.2	1.8	6.08	14.7	10.8	2480
	IDEA B Clear	7.2	11	8.2	23	<0.5	2.66	8.07	2.81	39000
	East Mat Pond	7.26	24	<0.5	16	1.1	3.73	9.97	6.9	1680
	IDEA B Clear	7.16	11	9.9	18.9	0.3	1.46	8.14	2.19	19500
	East Mat Pond	7.52	51	<0.5	22.8	2.5	3.63	12.1	5.31	1200
	IDEA B Clear	7.39	6	4.1	9.7	<0.5	0.501	6.2	0.345	19500
	East Mat Pond	7.39	70	<0.5	25.2	3.9	3.84	12.1	4.43	1200
	IDEA B Clear	7.21	2	0.9	2	0.1	0.104	5.58	0.051	12480
	East Mat Pond	7.35	18	<0.5	10.1	2	3.672	10.728	7.04	300
	IDEA B Clear	7.3	17	16.1	17.7	2.6	2.05	6.55	2.03	117000
	East Mat Pond	7.33	22	<0.5	16.6	0.6	3.15	11.1	6.63	1560
	IDEA B Clear	7.15	5	1.2	9.3	<0.5	0.58	6.11	0.931	14630
	East Mat Pond	7.5	39	<0.5	36.9	2.5	3.19	10.9	5.29	12800
	IDEA B Clear	7.22	1	<0.5	7.3	0.5	0.201	4.25	0.525	39000
	East Mat Pond	7.72	68	<0.5	19.7	5.3	3.94	10.8	3.26	5300
	IDEA B Clear	7.3	0	<0.5	4.8	2.1	0.127	5.58	0.38	39000
	East Mat Pond (FLOODED)	-	-	-	-	-	-	-	-	-
	IDEA B Clear	7.27	3	2.7	4.9	2.2	0.07	5.13	0.006	9310
	East Mat Pond	7.56	78	<0.5	20.3	<0.5	2.36	9.85	1.26	5000
	IDEA B Clear	7.26	3	2.7	6.1	<0.5	0.092	6.67	0.048	2600
	East Mat Pond	8.04	38	<0.5	22.9	0.9	2.2	7.8	1.04	7600
	IDEA B Clear	7.24	11	5.6	9.1	1	0.225	6.54	0.632	7000
	East Mat Pond	7.3	29	<0.5	19.2	4.8	3.43	11.8	5.47	4200
	IDEA B Clear	7.17	9	2.6	10.3	1	0.482	2.7	1.16	39000
	East Mat Pond	7.87	57	<0.5	16	0.8	3.29	12.5	3.69	39000
	IDEA B Clear	7.33	1	<0.5	2	0.7	0.079	4.85	0.074	19200
	East Mat Pond	7.88	49	<0.5	26.1	0.3	3.34	8.56	1.91	7000

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	IDEA B Clear	7.3	1	<0.5	3.28	0	0.153	4.66	0.485	39000
	East Mat Pond	7.98	48	<0.5	10.8	1.3	3.02	8.22	1.12	7400
	IDEA B Clear	7.31	6	5	4.62	0.6	0.479	7.62	0.768	39000
	East Mat Pond	7.87	23	<0.5	21.6	0.7	2.32	8.11	2.6	2200
	IDEA B Clear	7.24	20	19.3	12.7	0	1.06	9.39	1.89	6500
	East Mat Pond	9.63	74	<0.5	18.2	2.1	2.21	9.26	0.113	700
	IDEA B Clear	7.23	3	0.3	4.6	1.1	0.144	12	0.066	31200
	East Mat Pond	10.29	58	<0.5	12.8	3.7	1.53	9.61	0.027	20
	IDEA B Clear	7.46	2	<0.5	4.1	0.7	0.155	5.2	0.111	9600
	East Mat Pond	9.76	96	<0.5	11.5	4.2	1.86	9.51	0.076	620
	IDEA B Clear	7.62	4	2	2.8	1	0.108	4.63	0.044	29200
	East Mat Pond	9.77	85	<0.5	10.2	1.3	1.58	7.99	0.146	1000
	IDEA B Clear	7.44	1	<0.5	<1	0	0.068	5.6	0.039	15600
	East Mat Pond	9.28	42	<0.5	11.1	0.9	1.44	6.98	1.05	1320
	IDEA A Clear	7.57	4	3.6	3.97	0.4	0.158	5.04	0.173	24800
	East Mat Pond	8.96	49	<0.5	13.98	1.8	1.88	8.18	1.85	170
	IDEA A Clear	7.3	11	9.5	14.13	2.7	0.556	3.88	0.725	7200
	East Mat Pond	8.22	34	<0.5	17.5	1.8	1.43	6.91	1.1	7000
	IDEA B Clear	7.1	3	1.8	3.49	1.3	0.182	2.96	0.061	13600
	East Mat Pond	9.45	50	<0.5	13.3	1	1.78	7.3	0.359	500
	IDEA B Clear	7.29	4	3.1	8.6	0.2	0.088	2.73	0.059	52000
	East Mat Pond	8.98	55	<0.5	15.38	0.75	1.61	7.418	0.583	960
	IDEA B Clear	7.42	1	<0.5	2.86	8.3	0.328	5.572	0.032	65000
	East Mat Pond	9.41	79	<0.5	23.33	1.2	1.64	8.42	0.415	620
	IDEA B Clear	7.52	3	1.8	2.51	1.3	0.132	5.38	0.088	6400
	East Mat Pond	9.19	62	<0.5	18.25	3.4	1.35	6.68	0.381	6500
	IDEA B Clear	7.4	1	<0.5	2.75	3.2	0.082	3.77	0.311	11600
	East Mat Pond	8.61	44	<0.5	8.13	1	2.76	5.69	0.359	3900
	IDEA B Clear	7.33	2	0.6	2.74	1.6	1.48	5.79	0.09	9200
	East Mat Pond	9.04	52	<0.5	9.7	2.1	1.71	8.59	0.072	1640
	IDEA B Clear	7.34	1	<0.5	<1	0.7	0.315	6.4	0.017	19200
	East Mat Pond	8.59	43	<0.5	11.4	1.7	1.59	6.78	0.708	3400
	IDEA B Clear	7.46	0	<0.5	1.96	1.8	0.291	7.64	0.105	39000
	East Mat Pond	8.89	29	<0.5	5.3	1.2	1.27	5.31	0.529	6500
	IDEA B Clear	7.47	3	<0.5	4.9	0.5	0.207	4.79	0.099	19600
	East Mat Pond	9.03	41	<0.5	9.2	0.6	1.13	5.71	0.044	230
	IDEA B Clear	7.5	7	5.9	2.9	1.7	0.836	4.78	0.091	9100
	East Mat Pond	9.69	53	<0.5	11.4	2.1	1.34	6.07	0.093	380
	IDEA B Clear	7.7	7	5.3	3.92	3.4	0.804	5.49	0.033	39000
	East Mat Pond	9.17	47	2.5	12.1	6.2	1.28	6.42	0.175	420
	IDEA B Clear	7.35	2	0.7	4.1	2.7	0.099	6.67	0.135	9800
	East Mat Pond	9.14	51	8.6	14.58	14	1.23	7.45	0.019	840
	IDEA B Clear	7.61	3	2.4	4.55	0	0.522	6.12	0.017	16400
	East Mat Pond	8.87	39	<0.5	7.3	0.7	1.15	7.42	0.03	3900
	East B Clear	7.5	5	2.6	0.4	1	0.339	8.8	0.025	52000
	East Mat Pond	9.33	39	1.6	14.35	1.5	0.933	6.91	0.022	990
	East B Clear	7.4	5	2.6	6.7	0	0.398	9.87	0.165	65000

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	East Mat Pond	7.25	34	<0.5	19.2	1.7	0.977	8.03	2.11	52000
	East A Clear	7.05	6	4.9	14.4	0.6	0.435	4.05	0.164	22800
	East Mat Pond	8.74	24	<0.5	7.7	0.1	1.18	6.01	0.069	11200
	East B Clear	7.37	5	3.5	5	0	0.268	4.4	<0.005	39000
	East Mat Pond	8.89	37	<0.5	8.75	1.5	0.946	7.04	0.217	7200
	East B Clear	7.16	4	0.5	2.15	1.7	0.172	8.37	0.359	25600
	East Mat Pond	8.06	26	<0.5	11.9	2.5	1.08	8.16	0.336	900
	East B Clear	7.23	7	5	3.2	1.9	0.198	7.13	0.041	5700
	East Mat Pond	8.24	29	<0.5	10.5	2	0.728	6.31	0.326	800
	East B Clear	7.25	3	1.8	1.8	1.5	0.117	6.14	0.047	30400
	East Mat Pond	8.77	34	<0.5	18.3	0.6	0.864	7.69	0.836	1080
	East B Clear	7.37	3	<0.5	5.98	0	0.176	5.64	0.02	39000
	East Mat Pond	8.99	43	<0.5	14.1	5.8	0.877	8.24	0.204	300
	East B Clear	7.36	2	<0.5	1.93	4.6	0.131	4.67	0.044	39000
	East Mat Pond	7.81	57	<0.5	7.42	1.6	1.09	10.1	1	1580
	East B Clear	7.19	3	1.5	4.56	1.2	0.309	7.46	0.824	65000
	East Mat Pond	8.08	24	<0.5	12.1	1.3	0.872	6.81	1.45	120
	East B Clear	7.4	3	0.6	0.99	0	0.07	4.44	0.039	26000
	East Mat Pond	7.69	26	<0.5	16.3	1.2	0.758	7.12	0.755	290
	East B Clear									
	East ADP 003	7.53	8	#REF!	0.46	1.7	0.222	5.98	0.302	<10
	East ADP 003	7.84	6		0.53	1.8	0.26	6.7	0.178	10
	East ADP 003	7.5	4		0.33	1.3	0.249	7.23	0.133	<10
	East ADP 003	7.69	6		0.12	0.5	0.28	5.22	0.038	10
	East Idea ADP003	7.7	2		1.83	0.9	0.167	4.46	0.032	10
	East Idea ADP003	7.78	6		0.92	1.2	0.271	4.65	0.136	<10
	East Idea ADP003	7.56	5		<1	0.4	0.263	8.93	4.56	<10
	East Idea ADP003	7.67	6		1.91	0	0.186	3.89	0.225	<10
	East B Clear	7.66	5		1.5	0	0.226	2.29	0.158	<10
	East B Clear	7.75	6		0.59	0.9	0.307	2.58	0.882	<10
	East B Clear	7.59	5		0.7	1.9	0.222	4.68	0.048	<10
	East ADP003	7.52	14		0.52	0.4	0.573	5.77	0.049	<10
	East ADP003	7.66	16		0.35	0.7	0.611	4.97	0.286	<10
	East Idea ADP003	7.74	6		3.9	2	0.374	5.2	0.408	<10
	East Idea ADP003	7.63	5		0.86	1.2	0.437	4.65	0.076	<10
	East Idea ADP003	7.54	4		3.82	0.6	0.581	5.22	0.743	200
	East Idea ADP003	7.57	5		6.51	1.4	0.537	4.53	0.907	380
	East Idea ADP003	7.37	10		2.91	1.8	0.812	3.67	0.496	30
	East Idea ADP003	7.5	4		0.8	0.3	0.314	5.43	0.375	12
	East Idea ADP003	7.76	7		3.38	0.8	0.0354	5.56	0.168	130

EPA Licence Limits								
	pH - Lower Limit	pH - Upper Limit	Total Suspended Solids	BOD	Total Oils and Grease	Total Phosphorus	Total Nitrogen	Ammonia (NH ₄ ⁺)
90 percentile limit	-	-	20 mg/L	15 mg/L	-	1 mg/L	15 mg/L	5 mg/L
100 percentile limit	6.5	8.5	40 mg/L	35 mg/L	10 mg/L	3 mg/L	25 mg/L	10 mg/L