

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
#NAME?	ADP001	7.31	9.5		2.2	1.7	0.23	1.27	0.086	10000
	ADP001	8.41	25		3.4	2.7	0.42	1.66	1.569	700
	ADP001	7.17	8		3.5	2.6	0.14	1.32	0.101	100
	ADP001	6.9	11.5		3.2	0.9	0.12	1.22	0.056	120
	ADP001	8.26	13		3.4	0.5	0.12	1.18	0.005	1300
	ADP001	7.4	8		2.5	1.9	0.08	1.44	0.05	400
	ADP001	7.31	13.5	3.9	8.2	1.3	0.1	4.49	0.045	270
	ADP001	7.12	0.5	<0.5	0.9	2.4	0.04	2.01	0.07	110
	ADP001	8.56	<0.5	<0.5	1	<0.5	0.03	2.29	0.035	150
	ADP001	9.21	<0.5	<0.5	1.4	0.8	0.21	1.29	0.099	160
	ADP001	9.34	2.5	1.7	1.3	2.9	0.17	0.86	0.033	10
	ADP001	9.08	<0.5	<0.5	3.1	<0.5	0.13	0.79	0.022	160
	ADP001	7.87	3.5	2.9	1.7	4	0.11	0.94	0.031	610
	ADP001	7.92	19.5	11.6	6.3	13.5	0.2	2.04	<0.005	200
	ADP001	7.34	10	0.5	3.6	11.9	0.2	1.74	0.121	2000
	ADP001	6.82	4.5	0.5	2.6	1.8	0.12	2.02	0.092	400
	ADP001	7.12	9	0.9	2.2	0.7	0.16	1.33	0.084	250
	ADP001	7.22	16.5	0.9	4.3	0.9	0.17	1.38	0.01	700
	ADP001	7.19	22	0.9	7.7	0.6	0.24	5.54	1.313	110
	ADP001	6.89	3	0.9	3	<0.5	0.15	5.39	1.196	1800
	ADP001	8.95	7.5	0.9	2.2	<0.5	0.06	4.18	0.361	730
	ADP001	7.5	<0.5	<0.5	1.5	3.3	0.07	3.81	0.039	160
	ADP001	8.56	26	19.8	6.2	0.8	0.272	1.415	0.005	530
	ADP001	8.93	24.5	15.5	4.4	1.6	0.5	1.49	0.029	450
	ADP001	8.38	18	11.6	5.2	0.6	0.62	1.5	0.353	30
	ADP001	7.41	7.5	<0.5	3	1.1	0.324	1.786	0.161	110
	ADP001	7.62	10.5	0.8	3.5	1.2	0.31	1.5	0.138	750
	ADP001	7.31	14	<0.5	7.7	2.1	0.55	2.76	0.623	40
	ADP001	8.27	29	<0.5	5.4	<0.5	0.24	2.42	0.271	240
	ADP001	7.22	16	3.8	4.4	3	0.2	5.24	3.452	10500
	ADP001	7.03	12	7.5	4.9	1	0.25	5.93	4.658	100
	ADP001	7.09	5	4.1	1.6	6.8	0.233	5.32	3.621	150
	ADP001	6.93	8	6.8	1.3	<0.5	0.08	1.8	0.156	140
	ADP001	6.7	16	13.8	2.8	<0.5	0.18	2.33	0.175	160
	ADP001	6.92	19	14.7	4.1	1.8	0.15	1.32	0.112	50
	ADP001	7.79	17	4.3	3	1.4	0.2	1.3	0.041	380
	ADP001	7.87	9	5	2.5	0.6	0.12	1.22	0.035	110
	ADP001	8.16	7	2.2	2.1	4.7	0.27	1.27	0.09	3600
	ADP001	8.82	13	0.5	3.6	5.9	0.2	1.32	0.174	220
	ADP001	8.64	5.5	0.7	2.4	8.1	0.44	1.11	0.153	7200
	ADP001	8.71	14	4.9	2.7	2.3	0.37	1.26	0.137	120
	ADP001	7.43	5	0.3	3	1.9	0.42	7.06	5.064	800
	ADP001	7.41	2	0.8	1.9	1.1	0.42	3.44	0.215	130
	ADP001	7.49	5	3.4	2.5	<0.5	0.41	2.35	0.205	110
	ADP001	7.8	8	<0.5	3	<0.5	0.47	1.76	0.074	120
	ADP001	8.53	17	11.1	3	2.7	0.68	1.67	0.072	250
	ADP001	9.03	28.5	10.5	5.6	4.3	0.73	1.91	0.028	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	ADP001	8.16	18	<0.5	6.1	0.8	0.62	1.87	0.054	500
	ADP001	8.77	26	12.7	5.6	2.1	0.54	1.95	0.025	880
	ADP001	9.25	50	13.8	5.8	5.4	0.448	4.288	0.092	580
	ADP001	7.99	13	2	4.6	2.3	0.278	1.81	0.131	60
	ADP001	7.07	17	<0.5	2.4	2	0.167	1.86	0.574	40
	ADP001	8.06	36.7	18	3.6	<0.5	0.25	2.16	0.185	80
	ADP001	7.01	19	<0.5	5.8	2.3	0.333	7.18	4.09	2000
	ADP001	6.98	9.5	<0.5	4.8	4.8	0.13	2.88	0.728	150
	ADP001	7.24	2.5	1	1	0.8	0.106	1.48	0.423	30
	ADP001	7.1	7.5	2.6	1.66	<0.5	0.145	1.52	0.199	90
	ADP001	7.47	6	3.6	1.3	<0.5	0.146	0.988	0.109	20
	ADP001	7.84	11.5	3.6	2.3	1.5	0.207	2.01	0.011	170
	ADP001	8.08	13.5	<0.5	5.7	3.5	0.349	1.67	<0.005	30
	ADP001	7.93	4.5	<0.5	1.6	<0.5	0.352	1.15	0.111	40
	ADP001	6.92	11.5	<0.5	2.9	0.9	0.392	2.025	0.103	1010
	ADP001	8.16	15.5	<0.5	4	1.4	0.401	1.81	0.013	80
	ADP001	7.57	6.5	<0.5	3.1	3.2	0.349	2.5	0.384	80
	ADP001	7.31	14.5	<0.5	4.1	2.1	0.271	2.3	0.325	600
	ADP001	8.49	25	<0.5	9.1	2.4	0.317	2.31	0.094	3600
	ADP001	7.29	14	4.3	18.3	1.5	0.243	8.08	3.72	190
	ADP001	7.44	9	7.3	2.7	2.1	0.276	3.84	0.571	50
	ADP001	8.42	7	3.3	0.9	7.7	0.151	4.19	0.099	200
	ADP001	9.02	10.5	4.2	2	1.7	0.22	2.85	0.077	120
	ADP001	7.63	41	6.1	9.4	0.9	0.703	3.15	0.209	770
	ADP001	9.64	37	<0.5	7	1.4	0.545	3.54	<0.005	100
	ADP001	8.81	33	7.9	5.4	2.3	0.723	2.29	0.183	210
	ADP001	7.75	14	<0.5	3	1.9	0.48	2.424	0.369	920
	ADP001	8.79	26.5	<0.5	5	3.3	0.474	1.96	<0.005	150
	ADP001	8.09	26	9.8	3.6	11.2	0.579	2.22	0.128	1760
	ADP001	8.07	18.5	3.9	3.7	2.6	0.599	1.55	0.083	1710
	ADP001	7.97	19.5	<0.5	4.4	2.6	0.413	2.2	0.424	530
	ADP001	8.74	45	<0.5	9.5	3.1	0.284	3.39	0.379	3600
	ADP001	7.43	42	<0.5	16.2	2.1	0.315	3.1	0.367	330
	ADP001	7.38	26	24	2.8	2.2	0.323	2.55	1.04	160
	ADP001	7.61	14.5	11.9	1.8	1	0.213	1.82	0.164	200
	ADP001	9.03	39.5	<0.5	6.6	<0.5	0.383	2.46	0.086	690
	ADP001	8.04	37	5.2	6.5	<0.5	0.471	1.68	0.08	370
	ADP001	9.16	37.5	<0.5	4.7	2.9	0.771	2.64	0.02	430
	ADP001	9.33	24.5	6.6	6.1	<0.5	0.532	2.33	<0.005	100
	ADP001	9.38	40	<0.5	5.3	2.5	0.675	3.14	0.027	100
	ADP001	9.1	59	17.7	12.2	<0.5	1.092	3.983	0.018	120
	ADP001	8.84	50.5	0.8	10.9	<0.5	0.588	2.88	0.046	300
	ADP001	7.47	33.3	11.9	7.7	<0.5	0.25	3.2	0.97	1000
	ADP001	8.78	46	<0.5	10.2	2.2	0.314	5.33	0.488	730
	ADP001	7.48	50	<0.5	13.5	<0.5	0.274	9.31	0.996	310
	ADP001	7.83	29.3	20	4.5	0.5	0.202	3.34	0.247	10
	ADP001	7.6	18.5	13.6	2.6	0.3	0.169	2.15	0.222	30

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	ADP001	8.43	50.7	22	7	2.6	0.392	2.5	0.082	1000
	ADP001	9.5	35.5	6.5	3.9	<0.5	0.293	1.78	0.035	<10
	ADP001	8.58	34	<0.5	6.9	3.3	0.298	2.33	0.038	850
	ADP001	8.62	16	6.5	5.1	1.6	0.172	1.52	0.029	220
	ADP001	7.74	15	8.7	1.4	2.9	0.211	1.29	0.163	100
	ADP001	7.71	14	<0.5	4.4	0	0.271	1.55	0.099	160
	ADP001	7.81	16	<0.5	2.9	2.4	0.176	2.06	0.183	590
	ADP001	7.5	8	<0.5	2.5	3	0.18	1.41	0.192	110
	ADP001	7.54	8	0.6	1.7	3.9	0.16	1.07	0.201	210
	ADP001	7.46	7	5.6	0.8	5.1	0.2	1.04	0.296	3
	ADP001	7.14	2	1.3	2.5	3.3	0.08	3.52	2.56	20
	ADP001	7.05	175	174.2	3.3	4.2	0.068	3.92	0.715	840
	ADP001	6.97	12	<0.5	5.4	3.7	0.156	1.66	0.006	90
	ADP001	7.08	13	<0.5	3.2	0.7	0.133	1.74	0.047	300
	ADP001	6.97	11	<0.5	5.7	2.1	0.13	1.45	0.046	1340
	ADP001	6.95	13	<0.5	8.6	1.6	0.137	1.208	0.053	410
	ADP001	7.33	14	<0.5	6.6	1.4	0.197	2.38	0.106	4960
	ADP001	6.72	11	<0.5	6.5	15.8	0.139	1.95	0.676	1740
	ADP001	6.87	12	9	2.6	4.6	0.114	1.09	0.048	3800
	ADP001	6.78	4	2.8	3.8	2	0.148	2.54	<0.005	1840
	ADP001	6.95	5	3.5	4	1	0.137	2.65	0.009	130
	ADP001	7.43	20	<0.5	20	<0.5	0.264	3.92	0.119	520
	ADP001	7.54	20	<0.5	6.1	1.2	0.198	2.85	0.181	1820
	ADP001	7.23	9	6.6	2.9	0.1	0.285	3.82	0.203	100
	ADP001	7.25	4	2.8	2.2	6.6	0.31	5.17	0.085	70
	ADP001	7.28	13	<0.5	6.3	0.7	0.172	2.68	1.08	550
	ADP001	6.88	17	8.3	3.1	5	0.73	8.71	2.42	3900
	ADP001	6.86	13	3	4.2	1.1	0.101	1.33	0.013	1500
	ADP001	6.74	6	<0.5	4.5	1.5	0.099	1.32	0.398	3040
	ADP001	6.63	12	10	4	1	0.185	1.55	0.707	1440
	ADP001	6.72	11	8.5	6.3	<0.5	0.114	1.67	1.6	2160
	ADP001	6.66	6	2.3	4.5	1.4	0.1	1.92	1.62	1300
	ADP001	6.83	4	3.2	0.8	2.9	0.071	1.43	0.724	140
	ADP001	8.17	33	<0.5	9.5	1.9	0.161	6.461	0.972	390
	ADP001	7.38	22	<0.5	13.8	2	0.201	3.29	0.489	190
	ADP001	7.49	10	2.1	5.8	1.9	0.075	6.11	0.538	70
	ADP001	8.98	2	0.4	2.5	<0.5	0.079	2.1	0.266	40
	ADP001	8.04	17	<0.5	5.9	<0.5	0.376	1.57	0.257	2300
	ADP001	8.73	13	<0.5	2.9	1.7	0.295	1.64	0.173	60
	ADP001	9.33	16	3.1	4.9	1.9	0.194	1.42	0.073	210
	ADP001	7.71	21	1.1	6.7	0.6	0.27	2.06	0.138	840
	ADP001	7.82	23	7.8	8.7	0.3	0.319	2.86	0.422	260
	ADP001	9.94	50	<0.5	3.5	1	0.232	3.13	0.03	10
	ADP001	9.77	54	26.7	0.1	1.3	0.157	1.85	0.028	1300
	ADP001	8.25	26	13.7	1.5	0.4	0.083	8.57	0.159	3900
	ADP001	8.21	11	3.3	1.68	2.1	0.061	14.5	0.287	1320
	ADP001	7.83	16		2.61	0	0.122	12.8	0.7	100

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	ADP001	9.3	51		3.74	0.1	0.166	4.76	0.022	2600
	ADP002	8.25	54		3.36	0	0.276	2.06	0.133	1760
	ADP01	7.81	30		6.17	2.4	0.168	2.1	0.332	720
		9.21	53		4.52	0.1	0.447	2.23	0.062	300
	ADP001	9.14	54		10.15	0.6	0.372	4.75	0.336	3600
	ADP001	8.63	29		3.55	3.3	0.26	3.37	0.762	

EPA Licence Limits								
	pH - Lower Limit	pH - Upper Limit	Total Suspended Solids	BOD	Total Oils and Grease	Total Phosphorus	Total Nitrogen	Ammonia (NH ₄ ⁺)
90 percentile limit	-	-	-	-	-	1 mg/L	-	-
100 percentile limit	6.5	8.5	30 mg/L	20 mg/L	10 mg/L	3 mg/L	15 mg/L	5 mg/L