

DEVELOPMENT DESIGN SPECIFICATION

D2

PAVEMENT DESIGN

Amendment Record for this Specification Part

This Specification is Council's edition of the AUS-SPEC generic specification part and includes Council's primary amendments.

Details are provided below outlining the clauses amended from the Council edition of this AUS-SPEC Specification Part. The clause numbering and context of each clause are preserved. New clauses are added towards the rear of the specification part as special requirements clauses. Project specific additional script is shown in the specification as italic font.

The amendment code indicated below is 'A' for additional script 'M' for modification to script and 'O' for omission of script. An additional code 'P' is included when the amendment is project specific.

Amendment Sequence No.	Key Topic addressed in amendment	Clause No.	Amendment Code	Author Initials	Amendment Date
<i>EXAMPLE 1</i>	<i>Provision for acceptance of nonconformance with deduction in Payment</i>	<i>XYZ.00</i>	<i>AP</i>	<i>KP</i>	<i>June 1997</i>
1	Major Revision as per Aus-Spec Bulletin Board Release 10	All	AMO	SPM	April 2003
2	Revisions as per Aus-Spec Bulletin Board releases 11 & 12	All	AMO	SPM	April 2003
3	Councils added to table D2.1	D2.10 (1)	AO	SPM	September 2003
4	Flexible pavement courses altered	D2.10 (2)	AMO	SPM	September 2003
5	Surface type – Councils added	D2.16 (1)	AM	SPM	September 2003
6	Austrroads seal design	D2.17	A	SPM	September 2003
7	Add option for 7mm second seal for PWC	D2.17 (c)	A	SPM	September 2003
8	Design ESA's rationalised	D2.05 (5)	AMO	SPM	September 2003
9	Amended for new Clarence Valley Council	D2.10	MO	SPM	April 2004
10	Amended for new Clarence Valley Council	D2.16	MO	SPM	April 2004
11	Amended for new Clarence Valley Council	D2.10 D2.17	M	SPM	May 2004
12	Combine surface types in each Council to one common standard and delete reference to cul-de-sac in subclause 2	Table D2.16 D2.16.2	O	SPM	October 2006
13	Unbound pavement design remove reference to ARRB document and insert Austrroads pavement design manual.	D2.11	MD	SPM	July 2010
14	Removal of separate minimum pavement thickness for Clarence	D2.10.1	O	TJE	November 2020

© The AUS-SPEC Joint Venture date: Jan 2002 Copying for on selling strictly prohibited

CLAUSE	CONTENTS	PAGE
GENERAL		1
D2.01 SCOPE		1
D2.02 OBJECTIVES		1
D2.03 REFERENCE AND SOURCE DOCUMENTS		1
PAVEMENT DESIGN CRITERIA		2
D2.04 DESIGN VARIABLES		2
D2.05 DESIGN TRAFFIC		2
D2.06 SUBGRADE EVALUATION		3
D2.07 ENVIRONMENT		4
D2.08 PAVEMENT AND SURFACING MATERIALS		4
D2.09 CONSTRUCTION AND MAINTENANCE CONSIDERATIONS		5
PAVEMENT THICKNESS DESIGN		6
D2.10 PAVEMENT STRUCTURE - GENERAL		6
D2.11 UNBOUND GRANULAR FLEXIBLE PAVEMENTS (BITUMINOUS SURFACED)		6
D2.12 FLEXIBLE PAVEMENTS CONTAINING BOUND LAYERS (BITUMINOUS SURFACED)		6
D2.13 RIGID PAVEMENTS		7
D2.14 CONCRETE SEGMENTAL BLOCK PAVEMENTS		7
D2.15 CLAY SEGMENTAL BLOCK PAVEMENTS		7
SURFACING DESIGN		7
D2.16 CHOICE OF SURFACE TYPE		7
D2.17 SPRAYED BITUMINOUS SEALS (FLUSH SEALS)		8
D2.18 BITUMINOUS MICROSURFACING (COLD OVERLAY)		8
D2.19 ASPHALTIC CONCRETE		8
D2.20 SEGMENTAL PAVERS		8
DOCUMENTATION		9
D2.21 DESIGN CRITERIA AND CALCULATIONS		9

SPECIAL REQUIREMENTS 9

D2.22 RESERVED9

D2.23 RESERVED9

D2.24 RESERVED9

D2.25 RESERVED9

PAVEMENT DESIGN

GENERAL

D2.01 SCOPE

1. The work to be executed under this Specification consists of the design of the road pavement to meet the required design life, based on the subgrade strength, traffic loading and environmental factors, and including the selection of appropriate materials for select subgrade, subbase, base and wearing surface.

Design Criteria

2. The Specification contains procedures for the design of the following forms of surfaced road pavement construction:

***Surfaced
Pavement
Types***

- (a) flexible pavements consisting of unbound granular materials;
- (b) flexible pavements that contain one or more bound layers, including pavements containing asphalt layers other than thin asphalt wearing surfaces;
- (c) rigid pavements (ie. cement concrete pavements);
- (d) concrete or clay segmental pavements.

3. Consideration to the design of unsealed (gravel) pavements will only be given for minor rural subdivisions/developments in isolated rural areas where the access to the subdivision is via an existing unsealed road.

***Unsealed
Pavements***

D2.02 OBJECTIVES

1. The objective in the design of the road pavement is to select appropriate pavement and surfacing materials, types, layer thicknesses and configurations to ensure that the pavement performs adequately and requires minimal maintenance under the anticipated traffic loading for the design life adopted.

***Pavement
Performance***

D2.03 REFERENCE AND SOURCE DOCUMENTS

(a) Council Specifications

D1	-	Geometric Road Design
D4	-	Subsurface Drainage Design
C242	-	Flexible Pavements
C244	-	Sprayed Bituminous Surfacing
C245	-	Asphaltic Concrete
C247	-	Mass Concrete Subbase
C248	-	Plain or Reinforced Concrete Base
C254	-	Segmental Paving
C255	-	Bituminous Microsurfacing

(b) State Authorities

Roads and Maritime Services, NSW - Sprayed Sealing Guide, 1992.

(c) Other

AUSTROADS - Guide to Pavement Technology.

ARRB-SR41 - Australian Road Research Board, Special Report No. 41 - A Structural Design Guide for Flexible Residential Street Pavements, 1989.

Cement and Concrete Association of Australia
 CACA - T51 - Concrete Pavement Design for Residential Streets.

Concrete Masonry Association of Australia
 CMAA - T44 - Concrete Segmental Pavements - Guide to Specifying
 CMAA - T45 - Concrete Segmental Pavements - Design Guide for Residential
 Access Ways and Roads
 CMAA - T46 - Concrete Segmental Pavements - Detailing Guide.

Clay Brick and Paver Institute
 - Design Manual 1 - Clay Segmental Pavements, A Design and
 Construction Guide for Sites Subjected to Vehicular and
 Pedestrian Traffic

PAVEMENT DESIGN CRITERIA

D2.04 DESIGN VARIABLES

1. Regardless of the type of road pavement proposed, the design of the pavement shall involve consideration of the following five input variables:

Design Variables

- (a) Design Traffic
- (b) Subgrade Evaluation
- (c) Environment
- (d) Pavement and Surfacing Materials
- (e) Construction and Maintenance Considerations

D2.05 DESIGN TRAFFIC

1. The design traffic shall be calculated based on the following minimum design lives of pavement:-

Minimum Pavement Design Life

- (a) Flexible, Unbound Granular - 20 years
- (b) Flexible, Containing one or more bound layers - 20 years
- (c) Rigid (Concrete) - 40 years
- (d) Segmental - 25 years

2. Design traffic shall be calculated in equivalent standard axles (ESAs) for the applicable design life of the pavement, taking into account present and predicted commercial traffic volumes, axle loadings and configurations, commercial traffic growth and street capacity. For new subdivisions, the design traffic shall take account of both the construction traffic associated with the subdivision development and the in-service traffic for the subdivision and for any future developments linked to that subdivision. For interlocking concrete segmental pavements, the simplification of replacing ESA's with the number of commercial vehicles exceeding 3 tonne gross contained in CMAA – T45 is acceptable up to a design traffic of 10^6 . Beyond this, ESAs should be calculated.

Design Traffic

© The AUS-SPEC Joint Venture date: Jan 2002 *Copying for on selling strictly prohibited*

3. The pavement design shall include all traffic data and/or assumptions made in the calculation of the design traffic.

Traffic Data

4. In general, reference should be made to ARRB-SR41 for the calculation of design traffic volumes up to 10⁶ ESAs and AUSTRROADS Pavement Design for design traffic volumes approaching or exceeding 10⁶ ESAs.

Equivalent Standard axles

5. In the absence of other traffic data, the following traffic values (in ESAs) may be taken as a guide to the design traffic, but shall be subject to variation depending on the circumstances for the particular development.

Design ESAs

<u>Street Type:</u>	<u>Design ESA's - 20 year design life</u>	
Urban Residential	- Access Street	3 x 10 ⁵
	- Local Street	3 x 10 ⁵
	- Collector	1 x 10 ⁶
	- Local Distributor	2 x 10 ⁶
Rural Residential	- Cul-de-sac (up to 10 lots)	3 x 10 ⁵
	- Other	3 x 10 ⁵
Rural	- Up to 1000 AADT	1 x 10 ⁶
	- Over 1000 AADT	2 x 10 ⁶
Commercial and Industrial		5 x 10 ⁶

D2.06 SUBGRADE EVALUATION

1. Except where a mechanistic design approach is employed using AUSTRROADS Pavement Design, the measure of subgrade support shall be the California Bearing Ratio (CBR). Where a mechanistic design approach using linear elastic theory is employed for flexible pavements, the measure of subgrade support shall be in terms of the elastic parameters (modulus, Poisson's ratio).

California Bearing Ratio

2. The following factors must be considered in determining the design strength/stiffness of the subgrade:

Design Considerations

- (a) Sequence of earthworks construction
- (b) The compaction moisture content and field density specified for construction
- (c) Moisture changes during service life
- (d) Subgrade variability
- (e) The presence or otherwise of weak layers below the design subgrade level.

3. The subgrade Design CBR adopted for the pavement design must consider the effect of moisture changes in the pavement and subgrade during the service life, and hence consideration must be given to the provision of subsurface drainage in the estimation of equilibrium in-situ CBRs, and hence in the design of the pavement structure. Warrants for the provision of subsurface drainage are given in Specification for SUBSURFACE DRAINAGE DESIGN. If subsurface drainage is not provided, then the Design CBR adopted must allow for a greater variability in subgrade moisture content during the service life of the pavement, and hence a Design Moisture Content above the Optimum Moisture Content.

Design CBR

4. The calculation of the Design CBR shall be based on a minimum of three 4 day soaked CBR laboratory samples for each subgrade area, compacted to the relative density specified for construction, and corrected to allow for the effects of subsurface drainage (or

Calculation of Design CBR

© The AUS-SPEC Joint Venture date: Jan 2002 Copying for on selling strictly prohibited

lack of), climatic zone, and soil type if appropriate (as per the guidelines in ARRB SR41) to give an estimated equilibrium in-situ CBR. The Design CBR for each subgrade area is computed by using the appropriate formulae as follows:

Design CBR = Least of estimated CBRs, for less than five results

Design CBR = 10th percentile of all estimated CBRs, for five or more results
= $C - 1.3S$

Where C is the mean of all estimated CBRs, and
S is the standard deviation of all values.

5. Where practicable, the Design CBR obtained from laboratory testing should be confirmed by testing performed on existing road pavements near to the job site under equivalent conditions and displaying similar subgrades.

**Field
Confirmation**

6. The pavement design shall include a summary of all laboratory and field test results and assumptions and/or calculations made in the assessment of Design CBR.

**Summary of
Results**

D2.07 ENVIRONMENT

1. The environmental factors which significantly affect pavement performance are moisture and temperature. Both of these factors must be considered at the design stage of the pavement. Reference should be made to AUSTRROADS Pavement Design, ARRB-SR41, and to NAASRA (Now AUSTRROADS) - Guide to Control of Moisture in Roads.

Reference

2. The following factors relating to moisture environment must be considered in determining the design subgrade strength/stiffness and in the choice of pavement and surfacing materials:

- (a) Rainfall/evaporation pattern
- (b) Permeability of wearing surface
- (c) Depth of water table and salinity problems
- (d) Relative permeability of pavement layers
- (e) Whether shoulders are sealed or not
- (f) Pavement type (boxed or full width)

3. The effect of changes in moisture content on the strength/stiffness of the subgrade shall be taken into account by evaluating the design subgrade strength parameters (ie. CBR or modulus) at the highest moisture content likely to occur during the design life, ie the Design Moisture Content. The provision of subsurface drainage may, under certain circumstances, allow a lower Design Moisture Content, and hence generally higher Design CBR.

**Evaluate
Design CBR**

4. The effect of changes in temperature environment must be considered in the design of pavements with asphalt wearing surfaces, particularly if traffic loading occurs at night when temperatures are low, thus causing a potential reduction in the fatigue life of thin asphalt surfacing. The effect of changes in temperature environment should also be considered for bound or concrete layers.

**Temperature
Change**

5. The pavement design shall include all considerations for environmental factors, and any assumptions made that would reduce or increase design subgrade strength, or affect the choice of pavement and surfacing materials.

D2.08 PAVEMENT AND SURFACING MATERIALS

1. Pavement materials can be classified into essentially four categories according to their fundamental behaviour under the effects of applied loadings:

**Pavement
Classification**

- (a) Unbound granular materials, including modified granular materials
- (b) Bound (cemented) granular materials
- (c) Asphaltic Concrete
- (d) Cement Concrete

2. Surfacing materials can also be classified into essentially five categories or types:-

**Surfacing
Classification**

- (a) Sprayed bituminous seals (flush seals)
- (b) Asphaltic concrete and bituminous microsurfacing (cold overlay)
- (c) Cement Concrete
- (d) Concrete Segmental Pavers
- (e) Clay Segmental Pavers

3. Unbound granular materials, including modified granular materials, shall satisfy the requirements of the Construction Specification for FLEXIBLE PAVEMENTS.

4. Bound (cemented) granular materials shall satisfy the requirements of the Construction Specification for FLEXIBLE PAVEMENTS.

5. Asphaltic concrete shall satisfy the requirements of the Construction Specification for ASPHALTIC CONCRETE.

6. Cement concrete shall satisfy the requirements of the Construction Specifications for MASS CONCRETE SUBBASE, PLAIN OR REINFORCED CONCRETE BASE, or FIBRE REINFORCED CONCRETE, as appropriate.

7. Sprayed bituminous seals shall satisfy the requirements of the Construction Specification for SPRAYED BITUMINOUS SURFACING.

8. Concrete and clay segmental pavers shall satisfy the requirements of the Construction Specification for SEGMENTAL PAVING.

9. Bituminous microsurfacing (cold overlay) shall satisfy the requirements of the Construction Specification for BITUMINOUS MICROSURFACING.

D2.09 CONSTRUCTION AND MAINTENANCE CONSIDERATIONS

1. The type of pavement, choice of base and subbase materials, and the type of surfacing adopted should involve consideration of various construction and maintenance factors as follows:

- (a) Extent and type of drainage
- (b) Use of boxed or full width construction
- (c) Available equipment of the Contractor
- (d) Use of stabilisation
- (e) Aesthetic, environmental and safety requirements
- (f) Social considerations
- (g) Construction under traffic
- (h) Use of staged construction
- (i) Ongoing and long-term maintenance costs

These factors are further discussed in AUSTRROADS Pavement Design.

PAVEMENT THICKNESS DESIGN

D2.10 PAVEMENT STRUCTURE - GENERAL

1. The minimum pavement thickness, excluding the thickness of surfacings, for sealed roads shall be 300mm. **Minimum Pavement Thickness**
2. Notwithstanding subgrade testing and subsequent pavement thickness design, the thickness of sub-base and base layers for sealed roads shall not be less than the following:-
 - (a) Flexible pavement: Base 150mm
Subbase varies with minimum pavement thickness
 - (b) Rigid pavement: Subbase 100mm, Base 150mm
3. The subbase layer shall extend a minimum of 150mm behind the back of any kerbing and/or guttering. **Subbase Extent**
4. The base and surfacing shall extend to the face of any kerbing and/or guttering. Where the top surface of the subbase layer is below the level of the underside of the kerbing and/or guttering, the base layer shall also extend a minimum of 150mm behind the rear face of the kerbing and/or guttering. **Base Extent**
5. For unkerbed roads, the subbase and base layers shall extend at least to the nominated width of shoulder.
6. The pavement designer shall make specific allowance for traffic load concentrations within carpark areas (eg. entrances/exits). **Car Parks**
7. The pavement designer shall make provision for pavement layer drainage on the assumption that during the service life of the pavement ingress of water will occur. **Drainage**

D2.11 UNBOUND GRANULAR FLEXIBLE PAVEMENTS (BITUMINOUS SURFACED)

1. Unbound granular flexible pavements with thin bituminous surfacings, including those with cement or lime modified granular materials shall be designed in accordance with AUSTRROADS Pavement Design.

Deleted

D2.12 FLEXIBLE PAVEMENTS CONTAINING BOUND LAYERS (BITUMINOUS SURFACED)

1. Flexible pavements containing one or more bound layers, including cement stabilised layers or asphaltic concrete layers other than thin asphalt surfacings, shall be designed in accordance with AUSTRROADS Pavement Design.
2. As an alternative to AUSTRROADS Pavement Design for design traffic up to 10⁶ ESAs, bound layers may be assumed to be equivalent to unbound layers of the same thickness, and the pavement designed in accordance with ARRB-SR41, using Figure 7 (95% confidence limit curves).

D2.13 RIGID PAVEMENTS

1. Rigid (concrete) pavements, with design traffic up to 10⁶ ESAs shall be designed in accordance with either CACA –T51 or AUSTRROADS Pavement Design.
2. Rigid (concrete) pavements for design traffic above 10⁶ ESAs, the design shall be in accordance with AUSTRROADS Pavement Design.
3. Single lane concrete bus bays adjacent to a flexible pavement shall be designed in accordance with CACA -TN52.

***Rigid
(Concrete)***

D2.14 CONCRETE SEGMENTAL BLOCK PAVEMENTS

1. Concrete segmental pavements with design traffic up to 10⁶ estimated commercial vehicles exceeding 3T gross shall be designed in accordance with CMAA –T45.
2. For design traffic above 10⁶ estimated commercial vehicles exceeding 3T gross the design shall be in accordance with AUSTRROADS Pavement Design, with the calculation of design traffic in terms of ESAs.

***Concrete
Segmental***

D2.15 CLAY SEGMENTAL BLOCK PAVEMENTS

1. Clay segmental pavements with design traffic up to 10⁶ ESAs shall be designed in accordance with Design Manual 1 - Clay Segmental Pavements.
2. For design traffic above 10⁶ ESAs and up to 10⁷ ESAs the design shall involve consideration of both Design Manual 1 - Clay Segmental Pavements and AUSTRROADS Pavement Design, with the thicker and more conservative design of each of the two methods adopted.
3. For design traffic above 10⁷ ESAs, the pavement shall be designed in accordance with AUSTRROADS Pavement Design.

***Clay
Segmental***

SURFACING DESIGN

D2.16 CHOICE OF SURFACE TYPE

1. Except where the pavement is designed for concrete or segmental block surfacing, the wearing surface shall be a bituminous wearing surface as follows:-

***Bitumen
Wearing
Surface***

Local Government Area	Urban residential - Access & Local Streets	Urban - Collector & Local Sub-Arterial	Rural residential	Rural
All Councils	primer + asphalt	primer + asphalt	primer + asphalt	Prime & 2 coat flush seal

2. At intersection approaches with flush seals, on residential streets and within industrial/commercial zones, either bituminous microsurfacing or asphalt surfacing shall be provided within the vehicle braking and turning zones.

***Braking and
Turning Zones***

3. Variations to these requirements may be approved by Council in special circumstances.

Approval

D2.17 SPRAYED BITUMINOUS SEALS (FLUSH SEALS)

1. The design of sprayed bituminous (flush) seals, including primer seals, shall be in accordance with the RMS Sprayed Sealing Guide. Alternatively the Austroads design guide for seal design, "AP-2/90 Design of Sprayed Seals", can be used **Seal Design**
2. 7mm primer seals shall be indicated on the Drawings below all flush seals, bituminous microsurfacing, and asphalt surfacings. Where a 7mm primer seal is impractical, a 10mm primer seal shall be indicated in lieu. **Primer Seal**
3. Two-coat flush seals shall be double-double seals, comprising a minimum of two coats binder and two coats of aggregate. The preferred seal types are: **Two-Coat Flush Seals**

1st coat	14mm
2nd coat	10mm or 7mm
4. Single coat flush seals shall be allowable if bituminous microsurfacing (or asphaltic concrete) is to be applied as the finished surface. The preferred seal type is either 14mm or 10mm. **Single Coat Flush Seal**

D2.18 BITUMINOUS MICROSURFACING (COLD OVERLAY)

1. Bituminous microsurfacing, also referred to as 'cold overlay', shall be designed to provide a nominal compacted thickness of not less than 8mm. **Minimum Thickness**
2. As a minimum, a 7mm primer seal and a single coat flush seal shall be indicated on the Drawings below the bituminous microsurfacing. **Primer Seal and Single Coat Seal**

D2.19 ASPHALTIC CONCRETE

1. In urban residential access and local streets, rural or light trafficked commercial streets (design traffic up to approximately 3×10^5 ESAs), the asphalt mix design shall be either a 'high-bitumen content' mix or the ARRB Gap-graded mix in accordance with ARRB-SR41 and the Construction Specification for ASPHALTIC CONCRETE. **Light to Medium Traffic**
2. In urban residential collector and sub-arterial roads, medium to heavily trafficked commercial streets and in all industrial roads, the asphalt mix design shall be a dense graded mix in accordance with the Construction Specification for ASPHALTIC CONCRETE. **Medium to Heavy Traffic**
3. Asphaltic concrete surfacings shall be designed to provide a nominal compacted layer thickness of not less than 25mm on light to medium trafficked residential, rural and commercial streets, and 40mm on medium to heavily trafficked residential, rural or commercial roads and on all industrial and classified roads. **Minimum Thickness**
4. As a minimum, a 7mm or 10mm primer seal shall be indicated on the Drawings below the asphalt surfacing. **Primer Seal**

D2.20 SEGMENTAL PAVERS

1. Concrete segmental pavers shall be 80mm thick, shape Type A, and designed to be paved in a herringbone pattern. **Size and Shape**
2. Clay segmental pavers shall be 65mm thick, Class 4, and designed to be paved in a herringbone pattern.
3. The edges of all paving shall be designed to be constrained by either kerbing and/or guttering, or by concrete edge strips. **Edge Constraint**

DOCUMENTATION

D2.21 DESIGN CRITERIA AND CALCULATIONS

1. All considerations, assumptions, subgrade test results, and calculations shall be submitted with the pavement design for approval by Council. **Submission Details**
2. The Drawings shall clearly indicate the structure, material types and layer thicknesses of the proposed pavement and surfacing. **Drawings**

SPECIAL REQUIREMENTS

D2.22 RESERVED

D2.23 RESERVED

D2.24 RESERVED

D2.25 RESERVED