



NOTES

1. THE CATCHPIT SHALL BE CAST-IN-SITU, OR PRECAST SUBJECT TO APPROVAL BY COUNCIL. THIS PLAN SHOWS A CAST-IN-SITU CATCHPIT WITH A PRECAST LINTEL.
2. 900 X 600 CLEAR OPENING GULLY GRATE FRAME TO BE CAST INTO CONCRETE. GULLY GRATE AND FRAME TO BE CLASS D TO AS3996 AND HAVE AUSTRALIAN STANDARDS MARK CERTIFICATION CLEARLY SHOWN. GRATE TYPE TO BE APPROVED BY COUNCIL
3. GULLY PITS GREATER THAN 1200 DEEP (FROM GRATE LEVEL) REQUIRE SPECIAL COUNCIL APPROVED DESIGN OR SEPARATE ACCESS CHAMBER. REFER AS/NZ3500
4. CONCRETE IN PRECAST LINTELS TO BE GRADE N32
5. CAST IN SITU CONCRETE TO BE GRADE N25
6. REINFORCING BARS TO BE TO AS/NZS 4671.2001 PLACED CENTRALLY. 40mm END COVER
7. LIFTING ANCHORS TO BE 'SWIFT LIFT' OR EQUIVALENT 1.3 TONNE GALV. TO AS/NZS 4680 & FITTED TO MANUFACTURERS SPECIFICATION
8. KERB & GUTTER PROFILES SHOWN ARE TYPICAL ONLY. FOR ACTUAL PROFILES REFER TO DWG. R-03
9. ALL DIMENSIONS IN MM.

PRECAST LINTEL DETAIL

TYPE	'A'	'B'	'C'	'D'	'X'
ANTI-PONDING	1000	885			
SMALL (S)	2400	2040	1800	1970	400
MEDIUM (M)	3600	3240	3000	3170	690
LARGE (L)	4800	4440	4200	4370	690

LINTEL NOTE

PROTECT OUR WATERWAYS - FLOWS TO THE OCEAN
TEXT 40mm HIGH - LETTERS IMPRINTED 5mm INTO CONCRETE FACING FOOTPATH

REVISIONS	APP'D	DATE
B PIPE REMOVED FROM SECTION B-B	MK	19/02/2020
A ORIGINAL ISSUE	<i>[Signature]</i>	7/7/10

STANDARD DRAWINGS
**NORTHERN RIVERS
LOCAL GOVERNMENT**

**SIDE ENTRY GULLY PIT
& ANTI PONDING PIT
LIP IN LINE**

**STORMWATER
STANDARD
DRAWING
SW-01**

A	B		
---	---	--	--